



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection. Making a false statement may result in a fine or prosecution under the *Technical Standards and Safety Act*

Licence Number: 0076542380-c

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



August

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A Company Name: Little Gull Marina Ontario Corporation No., if applicable: 1297115

Operator Name (if different from above): Richard Carroll

Telephone No.: 7056579088 Fax No.: 7056578672 E-mail:

B Street No.: 144 Street Name / 911 Number / Address, if applicable: Mississauga Rd.

Town / City or Township / County: Buckhorn Province: Ontario Postal Code: K0L1J0

Mailing address if different from above.

C Street No.: Street Name / 911 Number / Address, if applicable:

Town / City or Township / County: Province: Postal Code:

Information on Container Refill Centre or Filling Plant

Location of facility.

D Street No.: 144 Street Name / 911 Number / Address, if applicable: Mississauga Rd. 88 Nearest Major Intersection:


Town / City or Township / County: Buckhorn Province: Ont. Postal Code: K0L1J0

Name of Licence Holder: Richard Carroll

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT): Richard Carroll ROT type: PPO-3



Municipality (or municipalities if the facility or its hazard distance touches multiple borders): Gooderham

Hours of operation:



This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name	Signature	Date (dd-mm-yyyy)
Name of Licence Holder: Richard Carroll		25/07/2011
Name of Senior Management person as defined in the Regulation holding the Record of Training: Richard Carroll		25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. 1999 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. N/A

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	250	95FO 29063
Tank 2:		
Tank 3:		

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 1 x 1000 USWG Portable: 10 x 100 lb. 25x20 lb Mobile: N/A
300 → 200 + 100

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Richard Carroll	Official Title Owner
Signature 	Telephone No. 705-657-9088
	Date (dd-mm-yyyy) <u>25/07/2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) Kelly,s Propane		For Office Use - Party No.	
Street No. 2085	Street Name / 911 Number / Address, if applicable Whitlinton Rd.		
Town / City or Township / Country Peterborough		Province Ontario	Postal Code K9J 7H6
Telephone No. 7057454629	Fax No. 7057453622	Contact Name Kevin Dupuis	
E-mail kdupuis@kellysfuel.com.			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>		For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage		Capacity stored off-site, in USWG	For Office Use - Party No.
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Richard Carroll		Official Title Owner	
Signature 		Telephone No. 705-657-9088	Date (dd-mm-yyyy) 25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

4500 Ltr. above ground gas tank 28.4 m from propane tank
200 gal died desiel 52 m from propane tank
400 Gal Furnace oil (House Basement 30 m from the propane tank)

Description of fire and emergency equipment indicated on facility site map.

There are two 10 lb ABC Dry chemical fire extinguishers in repair shop one at each door and one 10 lb. ABC fire extinguisher in store
There is one 20 lb ABC Dry chemical at the gasoline pump
There is one 20 lb. ABC Dry chemical at the Propane tank

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

E Stop at gate of propane compound
Gas pump has flow E stop
Propane tank is fitted with an internal valve which incorporates a manual valve as well as an excess flow control. This valve is also protected by a fusible link.

Maintenance and testing schedule for fire protection controls and devices.

Fire Extinguishers Checked three times a year
E stop for Propane tested Daily
Visual inspection of propane tank daily

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Richard Carroll		Official Title Owner
Signature 		Telephone No. 705-657-9088
		Date (dd-mm-yyyy) 25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name Richard Carroll	For Office Use - Party No.	Name Richard Carroll	For Office Use - Party No.
Official Title Owner		Official Title Owner	
Telephone No. 705 657 9088	Fax No.	Cell No. 705 927 2527	Fax No.
E-mail richard@littlegullmarina.ca		E-mail richard@littlegullmarina.ca	
Role and responsibilities in emergency First Responder 705 927 2527		Role and responsibilities in emergency If not on site will immediately attend site. 1) site security and evacuation 2) stop the flow of if possible 3) call 911 4) co-ordinate resources	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Address	
Name Donald Bowles	For Office Use - Party No.	Name RICHARD CARROLL	For Office Use - Party No.
Official Title Yard Foreman		Official Title OWNER	
Telephone No. 705 667 1458	Fax No.	Telephone No. (705) 657-9088	Fax No. (705) 657-8672
E-mail donald.bowles@sympatico.ca		E-mail richard@littlegullmarina.ca	
Role and responsibilities in emergency		Role and responsibilities in emergency FIRST RESPONDER	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name Don Mitchel	For Office Use - Party No.	Name Kevin Dupuis	For Office Use - Party No.
Official Title Chef	E-mail	Official Title General Manager	E-mail
Telephone No. 1800 374 4009 Cell 705 930 2434	Fax No.	Telephone No. 705- 745-4629	Fax No.
Role and responsibilities in emergency		Role and responsibilities in emergency Will proceed to site if required. Will activate ERAP if required	
Fire Services Address		Propane Supplier Address 2085 Whittington Rd. Peterboro Ont.	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name Steve Brokbank	For Office Use - Party No.	Name Pat Kempit	For Office Use - Party No.
Official Title Deputy Chief	E-mail	Official Title CAO	
Telephone No. 1 800 374 4009 cell 705 930 4885	Fax No.	Telephone No. 1800 374 4009	Fax No.
Role and responsibilities in emergency		E-mail	
Fire Services Address		Municipality Name and Address	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) RICHARD CARROLL	Official Title OWNER
Signature 	Telephone No. (705) 657-9088
	Date (dd-mm-yyyy) 25/07/2011



Technical
Standards and
Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

Daily / Monthly inspections

Tank is situated inside a fenced locked compound

Emergency Response Assistance Plan

Fire Boat stored on site

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)		Official Title	
Richard Carroll		Owner	
Signature		Telephone No.	Date (dd-mm-yyyy)
		(705) 657-9088	25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy)	Print Name of Training Provider: Kelly,s Propane
	Print Name of Instructor: BRuce Howson
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy)	Print Name of Training Provider: Little Gull Marina
	Print Name of Instructor: Richard Carroll
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy)	Print Name of Training Provider: Little Gull Marina
	Print Name of Instructor: Richard Carroll
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>RICHARD CARROLL</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>(705) 657-9088</i> Date (dd-mm-yyyy) <i>25/07/2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) 30/12/2011	Print Name of Training Provider: Kelly,s Propane
	Print Name of Instructor: Bruce Howson
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) 30/12/2011	Print Name of Training Provider: Little Gull
	Print Name of Instructor: Richard Carroll
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) 30/12/2011	Print Name of Training Provider: Little Gull Marina
	Print Name of Instructor: Richard Carroll
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>RICHARD CARROLL</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>(705) 657-9088</i>
	Date (dd-mm-yyyy) <i>25/07/2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).

If an emergency situation action all on site personal are advised to evacuate and call 911. Public notification is provided by local fire service.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

MEETING PLACE IN FRONT OF RESIDENCE ON PROPERTY, SAFETY PLAN IN PLACE FOR STAFF, SUPERVISOR ON DUTY AT TIMES OF OPERATION & WILL ACTIVATE EMERGENCY PLAN.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

IMMEDIATELY UPON AWARENESS OF EMERGENCY WILL ACTIVATE EMERGENCY PLAN, EVACUATE AREA ETC.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

Gate is locked with regular duty chain which can be cut with bolt cutters if required.

Describe how the licence holder will ensure continual flow of updated information to authorities.

Flow process chart is posted at propane dispenser

Annual review for all staff on the Emergency procedures

Little Gull Marina will activate and review the emergency response procedures annually

How long will it take the facility liaison person to respond to the site.

Richard Carroll immediate response (lives on site)

Don Bowles lives 5 min. away

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
RICHARD CARROLL	OWNER	
Signature	Telephone No.	Date (dd-mm-yyyy)
	(705) 657-9088	25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	49 m (lake)	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	49 m (lake)	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>RICHARD CARROW</i>	Official Title <i>OWNOR</i>
Signature <i>[Signature]</i>	Telephone No. <i>(705) 657-9088</i>
	Date (dd-mm-yyyy) <i>25/07/2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

Would like to see storage separate from filling area
IS all staff trained on fire extinguisher usage
2.5 Km to the closest year round water source
Fire Dept can not supply 375 GPM continuous at this location.

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by: 31 07 2011

(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name <i>Galway Cavendish & Harvey FIRE RESCUE</i>	<i>[Signature]</i>	<i>28 07 2011</i>

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mm-yyyy)



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes

No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

Would like to see storage separate from filling area
IS all staff trained on fire extinguisher usage
2.5 Km to the closest year round water source
Fire Dept can not supply 375 Gpm continuous at this location.

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by: 31 07 2011

(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name <u>Galway Cavendish & Harvey FIRE RESCUE</u>	<u>[Signature]</u>	<u>28 07 2011</u>

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>RICHARD CARROLL</u>	Official Title <u>OWNER</u>
Signature <u>[Signature]</u>	Telephone No. <u>(705) 657-9088</u>
	Date (dd-mm-yyyy) <u>17/08/2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

- 7 The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
- 8 GPS co-ordinates of the single largest vessel.
- 9 Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
- 10 Clear indication of the municipality or municipalities present within the circle.
- 11 Visual indication of property line information.
- 12 The location and name of roads within or abutting the site.
- 13 Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
- 14 Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
- 15 Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy)	Capacity of single largest propane storage vessel (USWG) 1,000 USWG.
Tank setback coordinates. Indicate placement on the map.	
Front: 49 m	Right side property line: 170
Rear: 800	Left side property line: 130
GPS coordinates of single largest vessel: N 44.72066 / W 78.32564	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) RICHARD CARROLL	Official Title OWNER
Signature 	Telephone No. (705) 657-9088
	Date (dd-mm-yyyy) 25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: None Address: City: Province Postal Code	X				0 m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. [Redacted]			3		30 m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: None Address: City: Province Postal Code	X				0 m
Commercial building units - continuous occupancy specifically hotels, campgrounds, and resorts. Name: None Address: City: Province Postal Code	X				0 m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: None Address: City: Province Postal Code	X				0 m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: None Address: City: Province Postal Code	X				0 m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) RICHARD CARROLL	Official Title OWNER
Signature 	Telephone No. (705) 657-9088 Date (dd-mm-yyyy) 25/07/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet


Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9	None	0
# 100	29.5	10	295
# 40	11.75	None	0
# 33.3	9.62	None	0
# 30	8.8	10	88
# 20	5.8	20	116
# 10	2.9	None	0
# 5	1.5	None	0
Total Cylinder Capacity 499 uswg			

Tanks Stored On-site Not Connected for Use


Tank Size in USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	40
Total Tank Capacity	0
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	499 uswg

Workshop



Fire extinguishers located at each red arrow



<p>Setback Distances to Site Boundary North: 800 m East: 170 m South: 49 m West: 130 m</p>	<p>Municipality Within the 1 psi Overpressure Circle Township of Galwey, Cavendish and Harvey</p>		<p>Map of Surrounding Area Little Gull Marina 144 Missisquoi Lake Rd Buckhorn, Ont. K0L 1J0 Lot 17, Concession 4 RRI Township of Cavendish</p>
<p>Capacity of Propane Storage Tank 1000 USWG</p>	<p>Municipal Contacts</p> <p>Pat Kamp Chief Administrative Officer/Economic Development Officer/Deputy Clerk Tel: 705-738-3800 ext. 235 Fax: 705-738-3801 Email: pkemp@galwey-cavendishharvey.ca</p>		<p>Don Mitchell Fire Chief Tel: 705-738-3800 ext. 222 Fax: 705-738-3801 Email: dmitche@galwey-cavendishharvey.ca</p>
<p>GPS Co-ordinates of Propane Storage Tank N 44.72066 W 78.32564</p>	<p>Chief Administrative Officer/Economic Development Officer/Deputy Clerk Tel: 705-738-3800 ext. 235 Fax: 705-738-3801 Email: pkemp@galwey-cavendishharvey.ca</p>		<p>Fire Chief Tel: 705-738-3800 ext. 222 Fax: 705-738-3801 Email: dmitche@galwey-cavendishharvey.ca</p>
<p>Circular Distance to 1 psi overpressure Denoted by circle centred on tank; radial distance = 195 m</p>	<p>701 County Road 36 Box 820, Boboygeon, Ont. K0M 1A0</p>		<p>701 County Road 36 Box 820, Boboygeon, Ont. K0M 1A0</p>

FIRE RTE 181

I

F

E

P
R
I
V
A
T
E

R
O
A
D

G
B

H

A

P

P
A
R
K
I
N
G

D

C

J


K

KEY

- A - 25 M HANGAR
- B - 52 M STORAGE
- C - 6 M STORE / SHOP
- D - 30 M RICK CARROLL
- E - 130 M HUGH MC CLALLAN
- F - 145 M CHRIS O'HERON
- G - 60.9 M STORAGE
- H - 76.4 M STORAGE
- I - 150 M WES BALL
- J - 28.4 M BULK GASOLINE TANK
- K - 34.7 M RETAIL GASOLINE MTR.
- P - PROPANE BULK STORAGE


Section B

1. Propane tank is located inside a locked chain link fenced compound.
2. The operating hours are 8 am. to 5 pm. Site not operated after dark.
3. Regular house cleaning practices in place.
4. Daily inspection done at the start of day results recorded on inspection form.
5. Every filled cylinder is weighed after filling to ensure it has not been overfilled. If the cylinder has been overfilled the excess propane is removed either by venting thru purge stack if it can be done safely.
6. Scale is zeroed before each transfer.
7. All valves are double checked to ensure they are turned off and not leaking before being returned to the customer









Setback Distances to Site Boundary North: 800 m East: 170 m South: 49 m West: 130 m	Municipality Within the 1 psi Overpressure Circle Township of Galway, Cavendish and Harvey	Map of Surrounding Area Little Gull Marina 144 Mississauga Lake Rd Buckhorn, Ont. K0L 1J0 Lot 17, Concession 4 RR1 Township of Cavendish
Capacity of Propane Storage Tank 1000 USWG		
GPS Co-ordinates of Propane Storage Tank N 44.72066 W 78.32564	Municipal Contacts Pat Kemp Chief Administrative Officer/Economic Development Officer/Deputy Clerk Tel: 705-738-3800 ext. 235 Fax: 705-738-3801 Email: pkemp@galwaycavendishharvey.ca	Don Mitchell Fire Chief Tel: 705-738-3800 ext. 222 Fax: 705-738-3801 Email: dmitchell@galway-cavendishharvey.ca
Circular Distance to 1 psi overpressure Denoted by circle centred on tank; radial distance = 195 m		701 County Road 36 Box 820, Bobcaygeon, Ont. K0M 1A0