



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection. Making a false statement may result in a fine or prosecution under the *Technical Standards and Safety Act*

Licence Number: 10954015 (000076639379)

Check applicable type of propane operations:

Cylinder Motor Fill Filling Plant Card Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A Company Name: Amco Darshan Gas Bar Ontario Corporation No., if applicable: 86724 6605 RT0001

Operator Name (if different from above): Jitendra Modi

Telephone No.: 519-744-4591 Fax No.: _____ E-mail: rahul3270@yahoo.ca

B Street No.: 280 Street Name / 911 Number / Address, if applicable: Victoria Street North

Town / City or Township / County: Kitchener Province: Ontario Postal Code: N2H 5E2

Mailing address if different from above:

C Street No.: _____ Street Name / 911 Number / Address, if applicable: _____

Town / City or Township / County: _____ Province: _____ Postal Code: _____

Information on Container Refill Centre or Filling Plant

Location of facility:

D Street No.: 280 Street Name / 911 Number / Address, if applicable: VICTORIA ST. NORTH Nearest Major Intersection: VICTORIA ST N @ ST. LEGER ST

Town / City or Township / County: KITCHENER Province: ON Postal Code: N2H 5E2

Name of Licence Holder: Amco Victoria Street Kitchener

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT): Jitendra Modi ROT type: PPO-3

Municipality (or municipalities if the facility or its hazard distance touches multiple borders): Regional Municipality of Waterloo (City of Kitchener)

Hours of operation: _____

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name	Signature	Date (dd-mm-yyyy)
Name of Licence Holder: <u>Amco Darshan Gas Bar</u>		
Name of Senior Management person as defined in the Regulation holding the Record of Training: <u>Jitendra Modi</u>	<u>Jitendra Modi</u>	<u>MAY 25, 2011</u>

UPDATES



Technical Standards and Safety Authority
www.tssa.org
14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. 2002 approx
Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. 2009 - updated piping

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	2000 uswg	95J33-2
Tank 2:		
Tank 3:		

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 Portable: 14 cylinders Mobile:
 217 USWG



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519 744 4594
	Date (dd-mm-yyyy) MAY 25, 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 2002 approx	Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. 2009 - updated piping
--	--

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	2000 uswg	95J83-2
Tank 2:	-----	-----
Tank 3:	-----	-----

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 Portable: 14 cylinders Mobile: -----



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) MAY 25, 2011.



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)
Activity Information

Name of Propane Supplier(s) Dowler-Karn Limited		For Office Use - Party No.	
Street No. 1714	Street Name / 911 Number / Address, if applicable Perth Line 163, RR#1		
Town / City or Township / Country St. Marys		Province Ontario	Postal Code N4X 1C4
Telephone No. 519-229-6300	Fax No. 519-229-6308	Contact Name Manager, Neil Primeau	
E-mail neilprimeau@dowlerkarn.com			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>		[REDACTED]	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage	Capacity stored off-site, in USWG	For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator	Date (dd-mm-yyyy) MAY 25, 2011.
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591	



Technical Standards and Safety Authority
www.issa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Full serve retail fuel operation - Gasoline - 4 dual pumps - 2 supreme, 6 regular, Diesel - 1 dual pump (diesel)

25,000L storage (supreme and diesel) , 45,000 regular gasoline.

Both tanks are located behind the kiosk (see facility drawing) - some distance from the propane dispenser.

Description of fire and emergency equipment indicated on facility site map.

Fire Extinguishers at the dispenser, in the kiosk and with each pump.

Master hydro shutoff inside manned kiosk.

Propane shutoff well marked on fuse panel.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

Master hydro shutoff allows for shut down of dispenser, closing valve and stopping flow of propane in the system.

Fusible links on tank as described under B-149 of the Ontario gas code - heat sensitive automatic closure valve - main spring closes when the link breaks, restricting the flow of gases/ liquid.

Maintenance and testing schedule for fire protection controls and devices.

Annual inspection - supplier of tank and system as required per B-149 gas code - copy left on site.

Fire extinguishers - annual inspection (external)

Dispenser - daily inspection - upon opening of facility.(draft included)

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) <i>MAY 25, 2011.</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.602.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name Jitendra Modi	For Office Use - Party No.	Name Jitendra Modi	For Office Use - Party No.
Official Title Owner-Operator		Official Title Owner-Operator	
Telephone No. ⁷⁴⁴ 519-744-4591	Fax No.	Cell No. ⁸⁹⁷⁻⁹⁴²⁴ 519-888-0424	Fax No.
E-mail rahul3270@yahoo.ca		E-mail rahul3270@yahoo.ca	
Role and responsibilities in emergency Ensure emergency response plan executed. Alert authorities following confirmation that staff/customers are evacuated.		Role and responsibilities in emergency Ensure emergency response plan executed. Alert authorities following confirmation that staff/customers are evacuated.	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name Rita Modi	For Office Use - Party No.	Name Jitendra Modi	For Office Use - Party No.
Official Title Spouse of owner		Official Title Owner-Operator	
Telephone No. 519-744-4591	Fax No. ⁸⁶⁹⁻⁹⁷⁶⁴	Telephone No. 519-744-4591	Fax No.
E-mail rahul3270@yahoo.ca		E-mail rahul3270@yahoo.ca	
Role and responsibilities in emergency Ensure emergency response plan executed. Alert authorities following confirmation that staff/customers are evacuated.		Role and responsibilities in emergency Ensure emergency response plan executed. Alert authorities following confirmation that staff/customers are evacuated.	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name Phil Mellor	For Office Use - Party No.	Name Neil Poineau	For Office Use - Party No.
Official Title Assistant Chief Fire Prevention Officer		Official Title St. Marys Branch Manager	
Telephone No. 519-741-2496	Fax No.	Telephone No. 519-229-6300	Fax No. 519-229-6300
E-mail phil.mellor@kitchener.ca		E-mail neilpoineau@dowlerkam.com	
Role and responsibilities in emergency Coordination of municipal fire services and resources during an emergency		Role and responsibilities in emergency Alert support services as necessary and address any concerns - implement supplier epi plan if required	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name Gary Mann	For Office Use - Party No.	Name CARLA LADD	
Official Title Deputy Chief		Official Title C.A.O.	
Telephone No. 519-741-2496	Fax No.	Telephone No. 519-741-2357	Fax No.
E-mail gary.mann@kitchener.ca		E-mail carla.ladd@kitchener.ca	
Role and responsibilities in emergency Coordination of municipal fire services and resources during an emergency		Municipality Kitchener (Regional Municipality of Waterloo)	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) MAY 25, 2011



Technical Standards and Safety Authority
www.issa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.
This dispenser has been installed to code and to achieve compliance with all regulatory standards.

[Large empty area with horizontal dashed lines for writing additional safety measures.]

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator	
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591	Date (dd-mm-yyyy) <i>MAY 25, 2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) May 21, 2011	Print Name of Training Provider: In-house
	Print Name of Instructor: Jitendra Modi
Training Date (dd-mm-yyyy) ROT when required 3 year expiry	Print Name of Training Provider: OPA (PPO-3)
	Print Name of Instructor: Neil Primeau - certified instructor - Dowler-Karn Limited
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) May 2011	Print Name of Training Provider: Inhouse training
	Print Name of Instructor: Jitendra Modi
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) Every 3 years based on expiry	Print Name of Training Provider: Ontario Propane Association (certified trainer from Dowler-Karn Limited)
	Print Name of Instructor: Neil Primeau
Training Date (dd-mm-yyyy) May 2011	Print Name of Training Provider: Inhouse
	Print Name of Instructor: Jitendra Modi
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) MAY 25, 2011.



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) January 15, 2012	Print Name of Training Provider: Inhouse
	Print Name of Instructor: Jitendra Modi
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) January 15, 2012	Print Name of Training Provider: Inhouse
	Print Name of Instructor: Jitendra Modi
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) In advance of expiry date (3 yrs)	Print Name of Training Provider: CPA - Dowler-Karn Limited
	Print Name of Instructor: Neil Primeau
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) MAY 25, 2011.



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
Staff member onsite will be responsible for following the ERP plan as trained and in the event of an emergency will give verbal warning to customers per ERP.
If 2 employees are working, then most senior staff member will assume lead role. All other warnings will be made through emergency response personnel.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).
In the event that a warning has been issued, authorities will be contacted via 911 and all employees and customers evacuated to the evac point as noted on the facility plan and as noted in the ERP. If safe to do so, the hydro shutoff will be activated to stop the flow of propane. These steps are noted in the ERP.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).
In the event of a suspected spill, fire, leak or explosion, the emergency coordinator (senior staff member working) will immediately call 911 once customers have been ushered to safety. Steps are noted in the ERP attached.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.
All equipment is readily accessible as it is an open air facility in a strip mall parking lot with a kiosk at the fuel dispensing area. Hydro shutoff is in kiosk.

Describe how the licence holder will ensure continual flow of updated information to authorities.
In an emergency, this will be done via phone or cellphone until emergency response services arrive. At that point, they will assume control of the location all related sharing of information. In a proactive manner, AMCo Victoria Street location ownership will provide site and facility information along with a copy their ERP to the Fire services when the RSMP is submitted for their review.

How long will it take the facility liaison person to respond to the site.
10 to 15 minutes from home.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator	
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591	Date (dd-mm-yyyy) MAY 25, 2011



Technical Standards and Safety Authority
www.lssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

- | | Yes | No |
|---|-------------------------------------|--------------------------|
| 1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Is there adequate night lighting at the site? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 6. Are weighing systems validated for accuracy? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 9. Is the schedule of maintenance and testing activities retained on site? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

- | | Yes | No |
|---|-------------------------------------|--------------------------|
| 1. Is a pressurized water system available at the propane facility site? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) | 28.6 | _____ |
| 4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only) | n/a | _____ |

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) MAY 25, 2011.



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes	No
<input checked="" type="checkbox"/>	<input type="checkbox"/>

If not, please explain (e.g., no fire services).

AWAITING RESPONSE. WILL FORWARD WHEN RECEIVED. (see email samples)

Fire services comments, if any:

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by: _____ (dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator		
Signature <i>Jitendra Modi</i>	<table border="1"> <tr> <td>Telephone No. 519-744-4591</td> <td>Date (dd-mm-yyyy) <i>MAY 25, 2011.</i></td> </tr> </table>	Telephone No. 519-744-4591	Date (dd-mm-yyyy) <i>MAY 25, 2011.</i>
Telephone No. 519-744-4591	Date (dd-mm-yyyy) <i>MAY 25, 2011.</i>		



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 05-19-2010	Capacity of single largest propane storage vessel (USWG) 2000
Tank setback coordinates. Indicate placement on the map.	
Front: <u>6.5m</u>	Right side property line: <u>67.3m</u>
Rear: <u>45.2m</u>	Left side property line: <u>7.9m</u>
GPS coordinates of single largest vessel: <u>42deg27'27.91"N / 80deg29'08.12W</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) <i>MAY 25, 2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) <i>MAY 25, 2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: Joseph and Company Inc. Address: 257 Victoria Street North City: Kitchener Province Ontario Postal Code N2H 5C5			x		66.07 m
Residential building units specifically permanent single family dwellings, condominiums, and apartments [Redacted]				x	29.58 m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: MY Convenience Store Address: 280 Victoria Street North, Unit 1 City: Kitchener Province Ontario Postal Code N2H 5C5				x	17.8 m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) <i>MAY 25, 2011</i>



Technical Standards and Safety Authority
www.tssa.ca

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity In USWG	Quantity	Total Volume In USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	14	81.2 uswg
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume In USWG
Total Tank Capacity		

Total Cylinder Capacity	81.2 uswg
Total Tank Capacity	0
Total Portable Capacity	81.2 uswg

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jilendra Modi	Official Title Owner-Operator	
Signature <i>Jilendra Modi</i>	Telephone No. 519-744-4591	Date (dd-mm-yyyy) MAY 25, 2011



Technical Standards and Safety Authority
www.issa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume In USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	14	81.2 uswg
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		


Total Cylinder Capacity	81.2 uswg
Total Tank Capacity	
Total Portable Capacity	81.2 Uswg

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jitendra Modi	Official Title Owner-Operator
Signature <i>Jitendra Modi</i>	Telephone No. 519-744-4591
	Date (dd-mm-yyyy) <i>MAY 25, 2011.</i>

AMCO Darshan Gas Bar
 280 Victoria Street North
 Kitchener, ON,
 N2H 5E2


Level 1 RSMP
 Map of Surrounding Area




○ Location of Dispenser

City of Kitchener Contact
 Carla Ladd — CAO
 200 King Street West
 Kitchener, ON.
 519-741-2357

Property Line Setbacks



Level 1 Facility Drawing
AMCO— Darshan Gas Bar—280 Victoria St. North, Kitchener, ON.



- Propane Dispenser (2,000uswg)
- Retail Kiosk
- ◊ Emergency Shutoffs (hydro and propane)
- Propane motor fill pump
- Fire extinguishers
- ▲ Fire Hydrant

