# Technical Standards and Safety Authority www.issa.org

Technical Standards and Safety Authority www.tsss.org 14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario MBX 2X4 Fax: 416.231.4903 Customer Service; 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

This Level 1 RSMP applies to: a facility with a total propane storage capacity of 5,000 USWG or less; or a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection	on.	For	Office Use Only	
Making a false statement may result in a fine or prosecu under the Technical Standards and Safety Act			Office dae offiny	
		-[[]		
Licence Number 6033141001-C				
Check applicable type of propane operations.				
Cylinder Motor Fill Filling Plant	Card/Keylock			
Submit along with this completed application a Facility Site Plan and a Map of the Surro	unding Area.			2)
SECTION A: GENI	ERAL INFORMA	TION		
The Undersigned applies to TSSA for a review for an RSN	AP under Ontario's	Technical Standa	rds and Safety Act,	
Propane Storage and Handling Regulation.				
A COMPANY NAME OF THE CONTAINS A	Th	Onta	rio Corporation No., if applicable	f.
Operator Name (if different from above)	- 1 12			
8 191 E				
Telephone No. Fax No. E-mail Address				1
B Street No. Street Name, Lot / Concession No.				
	CCT			
Town / City or Township / County	Provinc		Postal Code	
PORT COLISORNE		0N	179K 1301	]
Mailing address if different from above.  Street No.   Street Name, Lot / Concession No.				.
C Street No. Street Name, Lot7 Concession No.				
Town / City or Township / County	Provinc	ce	Postal Code	
Information on Container Refill Centre or Filling Plant Location of facility.				
Street Name, Lot / Concession No.	Neares	Imajorinlersection		
Town / City or Township / County	Province	3	Postal Code	<del>-</del>
Port colburne		OHT	173K   3NJ	<u>]</u> ]
Name of Licence Holder				$\Box$
TOM Jang.				
Name of a Senior Management person as defined in the regulation holding the Re	ecord of Training (ROT).	ROT	EN <sub>ER</sub>	1
			PP0-3	1
Municipality (or municipalities if the facility or its hazard distance touches multiple of the control of the c	le borders)			
Hours of operation.  Monday: 18 am 10 pm	Friday:	7 am 10 p	m	
Tuesday: 18 am 10 pm	Saturday:	8 am 10 p		8545
Wednesday:armi pm	Sunday:	8_am_10_p	m SC DEOF	WETTA
Thursday:am1Opm	Holiday:	8_am_10pi	mecel	VED S
			MAY II O	2012
			1.111 0 9	2012
This document is valid until the next licence renewal date. You a				NM
Declaration: I am aware that it is an offence to I hereby declare that the information I I			and	141
Print name	Signature	- 9	Date (dd-mm-yyyy)	
Name of Licence Holder TOM JUNG	- lon	~ TY	59092011	-
Name of Senior Management person as defined in the	UNG		<sub>22</sub> s2	
Regulation holding the Record of Training TAMIE	W. 13			



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Toronto Ontario M8X 2X4
Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

### SECTION A: GENERAL INFORMATION (cont'd)

ndicate the year the facility was establi 1985	, , , , , , , , , , , , , , , , , , ,
lentify the psig rating and serial number	er for each fixed propane storage tank on site.
PSIG	Serial Number
Tank1:	5563193
Tank2: N/A	LL LA
Tank2:	N/A
	red, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for
	and the capacity of each tank/vessel, on a separate document.
	7. 20
Fixed:	Portable: N/A Mobile: N/A
NO. AND RESERVED TO THE RESERVED OF THE PARTY OF THE PART	

Name of person completing this form (please print)	Official Title	
Ton Jung	Owner-	
Signature	Telephone No.	Date (dd-mm-yyyy)
Tom My	905 - 835 - 1196	9-9-2011



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

# SECTION A: GENERAL INFORMATION (cont'd)

**Activity Information** 

		020
Name of Propane Supplier(s)	ŀF	or Office Llee Dedukle
Street No. Street Name Lot / Concession No.		
The state of the s		No.
3089 Regional Rd 12		
Town / City or Township / Country	Province	Postal Code
Smith Ville	ONT	LOR 2AO
Telephone No. Fax No. Contact Name	1	
Telephone No. Fax No. Contact Name 877-873-740 905-945-0571 MAC Suthealum	id	
E-mail		
Name of Propane Transporter. If same as above, please check box.	F	or Office Use - Party No.
я		
Street No. Street Name Lot / Concession No.	•	
8	8.9	
Town / City or Township / Country	Province	Postal Code
Telephone No.   Fax No.   Contact Name		
1 (0) Mr. 19		•
E-mail		
Off-site Cylinder and/or Mobile Storage Capacity stored off-site	, in USWG Fo	r Office Use - Party No.
IJ/A		
Street No. Street Name Lot / Concession No.		
Town / City or Township / Country	Province	Postal Code
		Ï
Telephone No. Fax No. Contact Name		
Note: Customer storage is not considered off-site storage.		
<u> </u>		

Name of person completing this form (please print)	Official Title
PHUT MOT	oborder.
Signature	Telephone No. Date (dd-mm-yyyy)
com 1	(905) 835-1196 9-09-2011
S 09195 (11/10) Page 3 of 15	



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

#### SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.
Three underground Gassiine taks with total.
capacity of 9,0000 Liters.
Description of fire and emergency equipment indicated on facility site map.
Fire Extinguishers one in propune tout Dispenser
Cabinet, Ome In GAS Bar, 3 in GASoline Pump ARGA.
List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)
and describe their function, use and operation.
1. Fusible Link um ISC VALVE.
2. Imergency Stop push Button Mounted on Bullard
3. Power supply Breaker in GAS Bar - shuts off pump & CLUSES  Solemord.
Maintenance and testing schedule for fire protection controls and devices.
Maintenace and Test linder taken By superior propone.
According to superior propone's A Maintenace standard.
sh. scoredale for key Expment is pump (3 month)
ISC VALVE ( Smonth) PRUS ( Two Years >
Replacement as per provincial Regulation) ALSO site tests
Its Imergency stop Button once Per month.

Name of person completing this form (please print)	Official Title	
Told Jung	owner	
Signature	Telephone No.	Date (dd-mm-yyyy)
tion ful	905 835 1196	09-09-2011
ES 00105 (11/10) Page 4 of 15		



FS 09195 (11/10) Page 5 of 15

Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

# SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		S Esci	lity 24-Hour Contact Person	
Name .	For Office Use - Party No.	Name		For Office Use - Party No.
Official Title		Official 7	TAM'E JUNG	1000000 JETHER 1000000000000000000000000000000000000
Owner		Carried an overland and		N.
Telephone No.   Fax No. (905) 835 - 1194 (905)	(05) 835-8312	Cell No.	289-969-4115 Fax No.	Pus) 835-8312
E-mail		E-mail		0) 623 6372
Role and responsibilities in emergency		Role and	NG OKHIN @ HOTHAIL responsibilities in emergency	COM
co-ordinate site r	esponse		co-ordinate site	
2. Facility Contact Personnel - Alternate C	ontact	6. Name	of Facility Manager	
Name TAMIE TUNG	For Office Use - Party No.	Name		For Office Use - Party No.
Official Title		Official T		
Telephone No. S35 -8312 Fax No.		Telephor	ne No.	1 10=1= 0=10
F-ma"		E-mail	905) 835 - 1196 PAX NO.	は) 35-8372
RYUNGOKMIN @ Hotm	ail. Com			
Role and responsibilities in emergency		Role and	responsibilities in emergency	
co-ordinate site	Res Ponse		s-ordinate site	Response
3. Local Fire Services - Key Contact	A CONTRACTOR OF THE PARTY OF TH	7. Propai	ne Supplier Key Contact Person	
Thomas B. Caltwright	For Office Use - Party No.	Name	MAC suthealand	For Office Use - Party No.
Official Title Fire Unief.		Official Ti		
Telephone No. 965-834-4512 Fax No. 965-834-4512	835-1020	Telephon	e No. Fax No.	25 - 15 - 5ENO
E-mail		E-mail	11 /	(5) 945-05M
Role and responsibilities in emergency	ca	Role and	Suffier M @ Superior Pro	Pame: Cum.
	E (au)	1	responsibilities in emergency	
See FinoServico Informut  4. Local Fire Services - Alternate Contact				
Name		Name .	pal Contact	
MIRE BENDIA			Ashley Grigg.	
Official Title Fire Prevention Officer		Official Tit	le'.i.	1:-
	835-1020	Telephone	No. Fax No.	
E-mail		E-mail		05) 835-2939
m. Lee bendin a perticiburne Role and responsibilities in emergency	·, (a.	Municipali		
Δ		wunicipan	ty t	
ee fire Source Parformation !	Form (Attachcel)			
Declaration: I am a I hereby dec	ware that it is an offence clare that the information	to give fa I have gi	lse information in this document an ven here is true and complete.	d
Name of person completing this form (please prin			Official Title	
TOH JUNG			Dwner	1
Signature		-	Telephone No.	Date (dd-mm-yyyy)
Tom To		2	405 - 935 - 1191	9-09-2011



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903

Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

### SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.
13 North and Bornery
Emergency stop pushbutton V which Trips
The Dispenser pump and Choses the sulenoid
Misse VALVE upstream of the Huseis
o Fusible link will melt in a fire and cause the spring loaded isc
to Colose
· Emergency stop push button mounted on bullard will stut off
Power to the propune exampment when pushed. RoT holder
should do this when the is an emergery situation
· Muintenance & Testing Records - ensure that Maintenance &
Testing Record are kept and Made available for TSSA &
Fire Service
+ 118 SAVICE
@ SMALL JEAKS
· CLOSE ALL AALVES - clean people from the Immediate area.
. CALL superior propume. I stut off Power to dispenseisand Motor.
6 SMALL Fire
· Clear People from Inmediate area.
. De not extinguish fire unless fuel feeding the fire
can be shut off.
· Close touck value to stop flow of propone.
. Apply water to tank and piping exposed to heat.
. 1

Name of person completing this form (please print)	Official Title	
Told Jung	D.W.ner	
Signature	Telephone No.	Date (dd-mm-yyyy)
Tun Jung	(905) 835-11	96 09-09-2011



Technical Standards and Safety Authority Fax: 416.231.4903 www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4

Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

# SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Respo	nse Plan and Procedures provided to facility key contacts.	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
Mar 21, 2011	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training on the facility's Emerg	ency Management Procedures provided to staff.	
Training Date (dd-mm-yyyy)	Print Name of Training Provider: TOM JUNG OMTONIO Propone As	consation
Mar. 21. 2011	Print Name of Instructor: TOM TUNG < R-ROT # 38	1000
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	•
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
On-site specific training provid	ed to certificate holders / persons with Records of Training.	
Training Date (dd-mm-yyyy)	Print Name of Training Provider: TOH JUNG	
Mar. 16, 2011	Print Name of Instructor: Told Tolig	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Name of person completing this form (please print)	Official Title	
TOM JUNG	OWner	
Signature	Telephone No.	Date (dd-mm-yyyy)
- lond by	905 - 835 - 1196	9-09-2011



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

# SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Resp	onse Plan and Procedures provided to facility key contacts.
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training on the facility's Emer	gency Management Procedures provided to staff.
Target Date (dd-mm-yyyy)	Print Name of Training Provider: ToH JUNG
Mar. 21, 2012	Print Name of Instructor: Tom Take
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
(6) f)	Print Name of Instructor:
On-site specific training provid	ded to certificate holders / persons with Records of Training.
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
TOM JUNG	Owner	
Signature	Telephone No.	Date (dd-mm-yyyy)
Tom Ty	(905) 835 - 1196	109-09-2011

FS 09195 (11/10) Page 8 of 15



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fac 44 202 Fax: 416.231.4903 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

# SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions
Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
© Perator to Call 911 & superior propune - Immedate -
Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).  MEMORITO TO HIT STOP. CALL 911  PERMINENTED TO FLACUATE COME TO Meeting place. Due STOFF & BUSTOMERS. have been accounted for and if safe to do so operator will Notify Survey.  I Vacuation plan will be done as part of the PTI 911-62 training. Neighbour
Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).  OPERATER OR ROT HOLDER OF IMPERIOR Short down is hit.  Second CAR 15 TO SUPPLIED PLOTENTE
Describe provisions for fire department entry when there are no operations or staffing at the propane site.  Open Site, No Access Restrictions
Describe how the licence holder will ensure continual flow of updated information to authorities.  ULA Plione from Remote Location
How long will it take the facility liaison person to respond to the site.  I maned: whe many SMINUTES

Name of person completing this form (please print)	Official Title	
Tom Tung	owmer	
Signature	Telephone No.	Date (dd-mm-yyyy)
Tim W	(905) 835-1196	9-9-2011
FS 09195 (11/10) Page 9 of 15 (		



Technical Standards and Safety Authority www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903

Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

								-
OFOTIONS		A 10 11 15-20	<b>PREPAREDNESS</b>		~ BI ~ =	TO D A A A		
		// H/II B	DDFDVDFINIECC	DECD			LOOMS!	~
	0. LIVILIBLAI INCAN				( )   M - 3	I AND IN	4 4 - 6 3 11 11 11	41

The licence holder will complete Section B in consultation with the local Fire Services. 6. Building and Site Security and Procedures Yes No Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)? Is there adequate night lighting at the site? 2. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials? Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? Are weighing systems validated for accuracy? Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. No Yes Is a pressurized water system available at the propane facility site? 1. 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)

FS 09195 (11/10) Page 10 of 15

Olymer	
owner	
one No.	Date (dd-mm-yyyy)
5) 835-1196	09-09-2011
o	05) 835-1196



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Toronto Ontario M8X 2X4 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

# SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services. 8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services Has the local fire service had an opportunity to review the Emergency If not, please explain (e.g., no fire services).		es No			
Fire services comments, if any: See Fine Sourio information Form (Attached)					
	*				
	1				
To be completed by the Licence Holder					
In response to the above comments, the following action(s) is required	·				
The Licence holder will respond to the Local Fire Services comment	s hv				
(dd-mm-yyyy)					
LOCAL FIR	E SERVICES				
The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.					
Print name	Signature	Date (dd-mm-yyyy)			
Local Fire Services Name Of Colbono Fine	m Bendre	20/10/2011			

	1970 P. Children Brooks and Children Control C	
Name of person completing this form (please print)	Official Title	_
Tom TUNG	Owner	
Signature	Telephone No Date (dd-mm-yyyyy)	
- (on) US	(905) 835-1196 09-08-20	11
FS 09195 (11/10) Page 11 of 15		_



Technical Standards and Safety Authority Fax: 416.231.4903 www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

### SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

#### Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

- 1. The storage location of fixed, portable, and mobile vessels.
- 2. The maximum volume, types and storage location of hazardous materials.
- 3. Location of permanent structures on site.
- 4. Access and egress points and location of barriers.
- Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
- Location of emergency shut off/shut down switches/valves.

#### Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

- 7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
- GPS co-ordinates of the single largest vessel.
- 9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
- 10. Clear indication of the municipality or municipalities present within the circle.
- 11. Visual indication of property line information.
- 12. The location and name of roads within or abutting the site.
- 13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
- 14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
- 15. Complete "Required Mapping Information from Updated Site Plan" in table below .

#### Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy)	Capacity of single largest propane storagevessel (USWG)
09-09-2011	2000
Tank setback coordinates. Indicate placement on the Front:  Rear:    Tank setback coordinates   Indicate placement on the	Alight side property line: 39.5 44.5'  Left side property line: ?
GPS coordinates of single largest vessel: N 42	.89951° W 79.25468°

Name of person completing this form (please print)	Official Title	
TOM JUNG	Owner	
Signature	Telephone No.	Date (dd-mm-yyyy)
Tom Jung	1905, 835 -1196	09-09-2011

# SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula:

 $D = 16.94 \times (1.524 \times C)^{1/3}$ 

D = Distance to overpressure of 1 psi (meters)

C= Tank Total Capacity in USWG

Parameters:


Density of Propane is 0.5033 kg per litre @ 15 C

Assume all vessels are 80% full

1 gallon [US, liquid] = 0.003785411784 cubic meter

1 cubic metre = 264.17 USWG

#### Hazard Distance Chart (EPA-TNT model)



Name of person completing this form (please print)	Official Title	
TOM JUNG	Owner	
Signature	Telephone No.	Date (dd-mm-yyyy)
(67/1 . 30)	(905) 835-119	6 09-09-2011



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority
Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

# SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2. Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area  AND Name and Address of Closest Building or Feature				* Number of Buildings and Features (mark with an "X")		
Industrial buildings or parks or golf courses  Name: Address: Province Postal Code	X		2-10	114	Feature m	
				0	<u>19</u> m	
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes.  Name: Bridget3 aurdromed  Address: 285 main St W  City: Province Province Postal Code			X		<u>19</u> m	
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts.  Name: Address:  City: Province Postal Code	X				m	
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons.  Name:	X				m	
Emergency responders specifically fire stations, ambulance stations, and police stations.  Name: Address: Province Postal Code	X				m	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title			
Signature Summer Signature	Telephone No. 905-835-1196	Date (dd-mm-yyyy)		

FS 09195 (05/11) Page 14 of 15

<sup>\*</sup> For multi-unit buildings, count each unit as "1".



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772

### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

# SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

#### Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	12	69.6
# 10	2.9		
# 5	1.5		

#### Tanks Stored On-site Not Connected for Use

		\$ 1907E1 (4) F) 8
Tank Size In USWG	Quantity	Total Volume in USWG
		* .
4		
Total Tank Capacity		
Total Cylinder Capacity	/3 i	
Total Cylinger Capacity	//3 /	


Total Cylinder Capacity	69.6
Total Tank Capacity	
Total Portable Capacity	69.6

Name of person completing this form (please pri	int)	Official Title		
TOH JUNG		Oh	mer	
Signature		Telephone No		Date (dd-mm-yyyy)
ten En	20	(905)	835-1196	1106-90-90
FS 09195 (11/10) Page 15 of 15	(4 H2 W)			



# Main Street West and Elm Street





Location: 297 Main St. W. Port Colborne

Prepared: Sept. 2 2011

Tank Size: 2000 USWF Horizontal Tank

Tank Setbacks: 13.5m North 6m East, 39.5 South 7.8m West

Radius: 246m

GPS Coordinates : N42<sup>c</sup>89'951' E79<sup>c</sup>25'468'

Municipality: City of Port Colborne

City Clerk: Ashley Grigg

Address : City Clerke Office

66 Charlotte St. Port Colbrne L3K 3C8

SURVEYOR LAND ONTARIO

# 297 Main Street West

# Fire Service Information Form

# Review and Comments for Level 1 RSMP

Date:

October 2011

Reviewed By:

Michael Bendia, Fire Prevention Officer

# Note:

Some versions of Adobe Reader will not allow users to save this file after completion. Use compatible versions of Adobe software when possible.

The following information is being provided by the local fire service having jurisdiction for the propane facility referenced within the Level 1 RSMP submission. The fire service is providing the information under the requirements of O. Reg. 211/01 and exercising it's authority for review and comment. The following comments are being provided to the propane operator;

	Municipal Information
Municipality / Region	City of Port Colborne, Region of Niagara
Address	66 Charlotte Street
Address	
City	Port Colborne
Postal Code	L3K 3C8
Clerk	Ashley Grigg
Phone	905-835-2900 ext - 106
Fax	905-835-5746
Email	ashleygrigg@portcolborne.ca
Alternate (if applicable)	
Phone	
Fax	
Email	

Municipal Fire Department Information				
Fire Department Name	Port Colborne Fire & Emergency Services			
Address	3 Killaly Street West			
Address				
City	Port Colborne			
Postal Code	L3K 6H1			
Fire Chief	Thomas B. Cartwright			
Phone	905-834-4512			
Cell	905-651-3724			
Fax	905-835-1020			
Email	firechief@portcolborne.ca			
Alternate Contact	Michael Bendia, Fire Prevention Officer			
Phone	905-834-4512			
Cell	905-651-3773			
Fax	905-835-1020			
Email	mikebendia@portcolborne.ca			

# Fire Service Response Details

The fire service should identify how many fire stations are located in the municipality and reference an approximate distance to the closest municipal fire station for response. Municipal resources should be shown in this table since the contacted fire service may not be available to respond at all times.

How many fire stations are within the municipality?

What is the approximate distance to the propane facility from the closest municipal fire station (Km)?

1.3 klms

The fire service should provide the average response time for their first arriving crew from the closest responding station, including stations under agreement. The time noted should be used as an ordinary response time as other factors that increase response time are not predictable. The time to assemble a full complement of crews means that the fire service has established all operational tasks and staffing and resources are available to support the operational assignments. Average times should be noted as factors that influence response setup are not predictable.

What is the approximate First Response time? (First arriving crew to complete scene assessment)	3.5 mins
	10 mins
(All apparatus and crews arrive, operational assignments provided)	

# **Fire Service Equipment**

Provide a list of all fire service apparatus that will be responding to this specific propane site should an event occur. List apparatus as pumpers, tankers or aerial devices. Combination units should be shown for the intended use as a pumper or tanker. Note: Apparatus shown in this section are for information purposes only. Unforeseeable situations such as maintenance or other emergency responses may limit apparatus availability.

Total pump capacity may be limited by the water supply available or the number of apparatus available. Operations may require pumpers to be assigned to water supply and the site.

Truck ID (P1, T1 or L1)	Pumper	Tanker	Elevating Device	Pump Capacity (GPM or LPM)	Water Capacity (Gal or Litres)
Engine #1	Х			1050 gpm	600 gallons
Engine #2	х			1250 gpm	600 gallons
Rescue #1	х			1250 gpm	800 gallons
Tanker #1	х	х		1250 gpm	2000 gallons
Ladder #1	Х		х	1250 gpm	420 gallons
	W		Total Pump Capa	city available (units)	6050 gpm
	То	tal Mobile	Water Capacity availa	ble on trucks (units)	4420 gallons

# Fire Service Response Considerations

The engineer must consider your fire protection services capabilities when determining a mitigation strategy in the RSMP. It will be important to provide accurate information about response capabilities and training to ensure the RSMP closes any identified response gaps.

Current Level of HAZMAT training that the fire service has obtained

3 Technicians, Operations all others

Provide fire service operation details that a propane company could expect from your fire service in the event of a propane leak or fire.

(Example of Service Operations:

Dispatch protocols will have a 1st response alarm of 3 response locations including apparatus XYZ, establish water supply with apparatus abc, our fire service has awareness level training, will establish safety zones, control fire within training and operational limitations, fight fire from a safe distance, will await technical support from propane operator.)

First alarm response will consist of Engine #1, Engine #2, Rescue #1, Ladder #1, Car 1 & Car 2 from headquarters. Initial response will create safety zone and establish a water supply to fight a fire from a safe distance. Port Colborne Fire has mutual aid agreements with all fire Departments in the Niagara Region which will allow for the ability to request additional resources if required.

Port Colborne Fire is part of the Niagara Regional CBRNE Team, a propane leak or propane fire will initiate activation of the Regional Team.

Await technical support from the propane operator and the Niagara Regional CBRNE Team.

Car #1 - Fire Chief is responsible for coordination of fire services during an emergency and will be the liaison with property owner. Also administrator of fire department and advisor to municipal council. Car #2 -Fire Prevention Officer / Operations Coordinator Acts in the Fire Chief's role in his absence.

List all intervention capabilities that the fire service can provide. (Provide specific details that identify mitigation actions the fire service will perform for this specific site)

Eliminate all ignition sources.

Assist in the evacuation of nearby residents and arrange for shelter of the evacuated residents.

Apply water spray to reduce or divert possible vapour cloud.

Prevent spreading of vapours through sewers, and shut down nearby ventilation systems.

Assist Niagara Regional CBRNE Team and propane operator with hazard mitigation.

# Water Supply Comments Check the appropriate response that best suits the water flow situation identified by your fire department. Note: This information should also be shown in the Level 1 RSMP (page 10 of 15). The fire service has the capability to pump and maintain a continuous $\overline{}$ flow rate of 375 GPM at the referenced facility. The fire service DOES NOT have the capabilities to pump 375 GPM at the propane facilities location. The propane operator requires a level of fire protection services beyond the capabilities of the municipal fire department and will be responsible to assess other safety strategies beyond municipal fire protection. Fire Service Comments for Level 1 RSMP Section B **Emergency Response and Preparedness Plan** Section B- Page 4 Location of on site material safety data sheets not identified. Information identified on page 4 of RSMP not identified on site map. No description of how emergency controls operate is provided or who is responsible to activate these controls. No maintenance and testing records provided for review. Section B1-Page 5 No roles and responsibilities with regards to the operator(s) identified. No information provided that operators received instruction in emergency procedures or portable fire extinguishers. No information provided with regards to actions to be taken to control a leak in the transfer hose or propane piping or to deal with a small fire. No person identified to be responsible to account for staff or customers or any details with regards to a meeting place outside the hazard area. Should include a list of duties staff is expected to perform and where necessary coordinate with emergency services. Section B2-Page 6 More information required on this emergency stop button. Is this an additional emergency stop or the one referenced on page 4. OFSCFCB-Rev Draft 2 Fire Service Commentary Page 5 of 7

#### **Additional Fire Service Comments:**

Section B3-Page 7

Name of training providers and instructors not identified.

Did the Emergency Response Training address the following topics?

- situations such as hose leaks, propane piping leaks or a fire under or around the propane tank.
- procedures for filling, storing and transfers.
- actions to be taken when an emergency situation is identified and causes for a propane leak or fire.
- the uses of portable fire extinguishers.

**Emergency Management Procedures** 

- Procedure for notification of staff
- process for initiating the warning and actions as well as the communication with emergency response authorities.

Section B4-Page 8

No information with regards to future training has bee identified.

Section B5-Page 9

Very little information was provided on how the operator will address the issues of multiple commercial and residential buildings within the warning area of this site including a large residential apartment building directly across the street. Also no evacuation procedure for people on site or a safe area for anyone evacuated.

An external evacuation plan is warranted for this facility.

Section B6-Page 10

Documentation is requested to support the following.

- -procedures that record the inspection of hoses and inspection requirements for filling systems.
- procedures that include the process to isolate and purge any overfilled propane cylinders.
- -procedures in place to ensure that all valves are closed after the propane cylinders are filled.
- maintenance & test records

Section C

Appears to be incomplete.





Additional Fire Service Comments:					

30/10/2011 Date Michael Bendia

M Ben Cee