



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

- This Level 1 RSMP applies to:
- a facility with a total propane storage capacity of 5,000 USWG or less; or
 - a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection.
 Making a false statement may result in a fine or prosecution
 under the *Technical Standards and Safety Act*

Licence Number: 0032354001-C

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.

For Office Use Only

Intake Group

MAY 26 2011 M.J.

[Redacted]

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A Company Name: W. J. HEASLIP LTD. Ontario Corporation No., if applicable: 000075751

Operator Name (if different from above):

Telephone No.: 905-779-3467 Fax No.: 905-779-3856 E-mail: guyh@wjheaslip.com

B Street No.: 1030 Street Name / 911 Number / Address, if applicable: HALDIMAND ROAD 20

Town / City or Township / County: HAGERSVILLE Province: ONTARIO Postal Code: NOA 1H0

Mailing address if different from above.

C Street No.: Street Name / 911 Number / Address, if applicable:

Town / City or Township / County: Province: Postal Code:

Information on Container Refill Centre or Filling Plant

Location of facility.

D Street No.: 1030 Street Name / 911 Number / Address, if applicable: HALDIMAND ROAD 20 Nearest Major Intersection: HALDIMAND ROAD 20 and HIGHWAY 3

Town / City or Township / County: HAGERSVILLE Province: ONTARIO Postal Code: NOA 1H0

Name of Licence Holder: W. J. HEASLIP LTD.

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT): GUY HEASLIP ROT type: PP0-3

Municipality (or municipalities if the facility or its hazard distance touches multiple borders): HALDIMAND COUNTY

[Redacted]

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name Name of Licence Holder: W. J. HEASLIP LTD.	Signature 	Date (dd-mm-yyyy) 18-04-2011
Name of Senior Management person as defined in the Regulation holding the Record of Training: GUY HEASLIP		



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 1983 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment.

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	<u>250 psig</u>	<u>9D0-7482-2</u>
Tank 2:	_____	_____
Tank 3:	_____	_____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 1000 uswg Portable: 535.2 uswg Mobile: NONE



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>GUY HEASLIP</u>		Official Title <u>CHIEF FINANCIAL OFFICER</u>	
Signature 		Telephone No. <u>905-779-3467</u>	Date (dd-mm-yyyy) <u>18-04-2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) SPARLING'S PROPANE COMPANY LTD.		For Office Use - Party No.	
Street No. 183	Street Name / 911 Number / Address, if applicable INDUSTRIAL BLVD		
Town / City or Township / Country ST. GEORGE		Province ONTARIO	Postal Code NOE 1N0
Telephone No. 1-866-517-1714	Fax No. 519-448-3450	Contact Name TIM WOLFE	
E-mail tew@sparlings.com			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>		For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage		Capacity stored off-site, in USWG NONE	For Office Use - Party No.
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 	Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Other hazardous materials stored on site include gasoline, diesel fuel and dyed diesel fuel. All three are stored in above ground storage tanks (2200 litre each tank) located 23 metres from the propane tank. The fuel is utilized for private use only. Small quantities of gasoline and diesel fuel are kept in portable containers in boxes located outside of each repair shop. Oxygen and acetylene cylinders are kept in a cage outside the small motor repair shop 25 metres from the propane tank. Typically 3 of each gas is kept and used by the mechanics in both repair shops.

Description of fire and emergency equipment indicated on facility site map.

One 20BC fire extinguisher is kept at the dispenser. There are an additional 14 fire extinguishers located on site throughout the buildings. An emergency cut-off (ECO) switch located on a post at the dispenser that terminates power to the propane pump and solenoid valve on the liquid propane line.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

The ISC valve at the tank liquid outlet is equipped with a fusible link, which when exposed to excessive heat will melt allowing the ISC to close.

The ISC valve remains closed when the dispenser is not in use. Due to the physical layout, when the cabinet door is closed the ISC is also shut off.

The ECO switch is located adjacent to the dispenser. When activated, power is terminated to the propane pump and the solenoid valve in the liquid propane line. The main breaker is located in the hydro panel inside the side door of the main store which is adjacent to the dispenser.

Maintenance and testing schedule for fire protection controls and devices.

The annual maintenance and dispenser inspection is performed by Sparling's Propane. The license holder performs daily recorded visual inspections of the equipment and area. Any deficiencies found are reported to Sparling's Propane for repair immediately. The license holder maintains a record of monthly testing of the ISC valve and the ECO operation. The fire extinguishers are maintained in accordance with applicable Provincial and Municipal Regulations.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 		Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario MBX 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact

Name: GUY HEASLIP
Official Title: CHIEF FINANCIAL OFFICER
Telephone No.: 905-779-3467
Fax No.: 905-779-3856
E-mail: guyh@wjheaslip.com
Cell #: 905-512-6744

Role and responsibilities in emergency
Assist emergency services as required

5. Facility 24-Hour Contact Person

Name: GUY HEASLIP
Official Title: CHIEF FINANCIAL OFFICER
Cell No.: 905-512-6744
Fax No.: 905-779-3856
E-mail: guyh@wjheaslip.com

Role and responsibilities in emergency
Assist emergency services as required

2. Facility Contact Personnel - Alternate Contact

Name: ROB HEASLIP
Official Title: PRESIDENT
Telephone No.: 905-779-3467
Fax No.: 905-779-3856
E-mail: robh@wjheaslip.com
Cell #: 905-541-4551

Role and responsibilities in emergency
Assist emergency services as required

6. Name of Facility Manager

Name: GUY HEASLIP
Official Title: CHIEF FINANCIAL OFFICER
Telephone No.: 905-779-3467
Fax No.: 905-779-3856
E-mail: guyh@wjheaslip.com
Cell #: 905-512-6744

Role and responsibilities in emergency
Assist emergency services as required

3. Local Fire Services - Key Contact

Name: ROB GRIMWOOD
Official Title: FIRE CHIEF
Telephone No.: 905-318-0159 ext 229
Fax No.: 905-701-0200
E-mail: rgrimwood@haldimandcounty.on.ca

Role and responsibilities in emergency
Manage emergency response

7. Propane Supplier Key Contact Person

Name: TIM WOLFE
Official Title: REGIONAL MANAGER
Telephone No.: 1-866-517-1714
Fax No.: 519-448-3450
E-mail: tew@sparlings.com

Role and responsibilities in emergency
Key Contact to activate Sparling's Propane ERAP # 2-0220

4. Local Fire Services - Alternate Contact

Name: ALAN GEE
Official Title: FIRE PREVENTION OFFICER
Telephone No.: 905-318-0159 ext 242
Fax No.: 905-701-0200
E-mail: agee@haldimandcounty.on.ca

Role and responsibilities in emergency
Assist with management of emergency response

8. Municipal Contact

Name: ROB GRIMWOOD
Official Title: FIRE CHIEF
Telephone No.: 905-318-0159 ext 229
Fax No.: 905-701-0200
E-mail: rgrimwood@haldimandcounty.on.ca

Municipality: Haldimand County

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 		Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

There are fourteen (14) additional fire extinguishers available at the facility, ranging in rating from 1A 10BC to 6A 80BC.

The facility is located in a rural area, with no hydrant presence. There is a cistern under the building 40 feet by 80 feet by 6 feet deep that is naturally filled with water that could be used by fire services. Access to the cistern is through grated openings across the front of the main store.


A sign is affixed to the dispenser identifying Sparling's Propane as the fuel supplier as well as posting the Sparling's 24/7 emergency response phone number (1-866-517-1714).

The dispenser cabinet remains closed except when being used thereby closing the ISC valve by way of a lever extension that prohibits the cabinet door from being shut if the ISC valve is in the open position. The cabinet door is locked when the facility is closed.

Visual inspections are performed and recorded by the operator on days of operation.

Monthly inspections of the fire extinguisher and testing of the ECO switch and ISC valve are performed and recorded by the operator.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 	Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) June 7, 2010	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) June 7, 2010	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) June 7, 2010	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 		Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) June 7, 2011	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) June 7, 2011	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Target Date (dd-mm-yyyy) As needed (new hires)	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) June 7, 2011	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Target Date (dd-mm-yyyy) As needed (new hires)	Print Name of Training Provider: W.J. Heaslip Ltd.
	Print Name of Instructor: Guy Heaslip
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP	Official Title CHIEF FINANCIAL OFFICER
Signature 	Telephone No. 905-779-3467
	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate). Also see Emergency Response Procedures (Tab 8)

The facility attendant will notify management in the event of an emergency situation. In the event that the attendant is not present all employees are trained to report emergency situations to the office. Management will use the paging system to alert employees and customers of the need to evacuate the premises.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

All employees have been trained that when an evacuation order is announced or an evacuation is otherwise necessary, they are to leave the property immediately and report to the meeting place at the "Stihl" sign at the road. Management is responsible for notifying emergency services. Management will take a roll call and will confirm emergency services have been notified of the emergency. This information will be passed on to the key contact or emergency services as required. All customers on the premises will be ordered to evacuate with the employees.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

The manager or senior staff are responsible for calling 911 in an emergency.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

The fire services has 24 hour access to the propane dispenser, however the cabinet housing the dispensing equipment is left closed and locked when not open for business.

Describe how the licence holder will ensure continual flow of updated information to authorities.

Once emergency services have been notified, the key contacts for W.J. Heaslip are to be contacted, if not on site. It is their responsibility to ensure that information is passed on to the authorities. Until their arrival the on duty manager will provide information to emergency services.

How long will it take the facility liaison person to respond to the site.

1-2 minutes

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 	Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

- | | Yes | No |
|---|-------------------------------------|-------------------------------------|
| 1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Is there adequate night lighting at the site? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 6. Are weighing systems validated for accuracy? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 9. Is the schedule of maintenance and testing activities retained on site? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

- | | Yes | No |
|---|----------------------------|-------------------------------------|
| 1. Is a pressurized water system available at the propane facility site? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) | <u>9000 Metres-shuttle</u> | |
| 4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only) | <u>9000 Metres-shuttle</u> | |

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP	Official Title CHIEF FINANCIAL OFFICER	
Signature 	Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes

No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

FIRE DEPARTMENT CAN ONLY SUPPLY 200 GPM AS PER ACCREDITATION THROUGH FIRE PROTECTION SURVEY SERVICES.

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by:

(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name <i>Rob Grimwood</i>	<i>R/Grimwood</i>	<i>31-05-2011</i>

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP	Official Title CHIEF FINANCIAL OFFICER
Signature <i>Guy Heaslip</i>	Telephone No. 905-779-3467
	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario MBX 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) April 1, 2011	Capacity of single largest propane storage vessel (USWG) 1000 uswg
Tank setback coordinates. Indicate placement on the map.	
Front: <u>12.1 metres</u>	Right side property line: <u>146 metres</u>
Rear: <u>54.25 metres</u>	Left side property line: <u>66.75 metres</u>
GPS coordinates of single largest vessel: <u>North 42.55.626 by West 079.57.303</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP	Official Title CHIEF FINANCIAL OFFICER
Signature 	Telephone No. 905-779-3467 Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 		Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>Armstrong Milling</u> Address: <u>1039 Haldimand Road 20</u> City: <u>Nelles Corners</u> Province <u>Ontario</u> Postal Code <u>N0A 1H0</u>		x			<u>50.4</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. [Redacted]				x	<u>67.2</u> m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>Schweyer Seeds</u> Address: <u>1080 Haldimand Road 20</u> City: <u>Nelles Corners</u> Province <u>Ontario</u> Postal Code <u>N0A 1H0</u>			x		<u>130</u> m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP	Official Title CHIEF FINANCIAL OFFICER	
Signature 	Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5	6	177
# 40	11.75		
# 33.3	9.62	10	96.2
# 30	8.8	10	88
# 20	5.8	30	174
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity	535.2 uswg		


Tanks Stored On-site Not Connected for Use


Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	535.2
Total Tank Capacity	0
Total Portable Capacity	535.2 uswg

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) GUY HEASLIP		Official Title CHIEF FINANCIAL OFFICER	
Signature 		Telephone No. 905-779-3467	Date (dd-mm-yyyy) 18-04-2011




 Denotes access and egress routes

Site Plan for Propane Dispenser:
 W.J. Heaslip Ltd.
 1030 Haldimand Road 20
 Hagersville, Ontario



AERIAL MAP of W.J. HEASLIP LTD.

1030 HALDIMAND ROAD 20, HAGERSVILLE, ONTARIO



<p>Facility Address: 1030 Haldimand Road 20, Hagersville, Ontario</p>	<p>Legal Description of Property: RNH Con 9 Pt Lot 2RP 18R1152 parts 1 and 2 and RP18R5998 Part 1, Haldimand County</p>
<p>Municipal Contact Information: Evelyn Eichenbaum Municipal Clerk, Haldimand County 45 Munsee St. N., P.O. Box 400 Cayuga, Ontario N0A 1E0 905-318-5932</p>	<p>Date Map Prepared: April 1, 2011.</p>