Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

a facility with a total propane storage capacity of 5,000 USWG or less; or
a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

			orm may result in rejection. esult in a fine or prosecution ndards and Safety Act			
Check	applicable type of Cylinder	Motor Fill	Filling Plant Card/Keyld	ick		
		s	ECTION A: GENERAL IN	FORMATION		
	pane Storage	applies to TSSA for and Handling Regula	a review for an RSMP under ation.	Ontario's Technical S.		
	Company Name				Ontario Corporation No., if applicable	
A	Canadian Tire C					
		different from above) Saeed (Agent)tel: 416	-259-2724			
	Telephone No.	Fax No.	, E-mail			
	416-544-7608	416-544-6163	john.lastoria@cantire.com			
В	Street No.	Street Name / 911 Number	er / Address, if applicable		ľ	
	2180	Yonge Street, 17th Flo	oor			
	Town / City or Tow	nship / County		Province	Postal Code	
	Toronto			Ontario	M4P 2V8	
		if different from above.				
C	Street No.	Street Name / 911 Number				
		P.O. Box 770 Station	K (Account #34421)	12000000		
	Town / City or Town	nship / County		Province Ontario	Postal Code M4P 3J5	
-	Toronto	toines Belill Contra on	Filling Dlont	Ontario		
Ini	Location of facili	ontainer Refill Centre or tv.	rilling Plant			
_	Street No.	Street Name / 911 Number	er / Address, if applicable	Nearest Major Intersection	1	
D	1612	The Queensway		The Queensway & The	East Mall	
	Town / City or Tow	nship / County		Province	Postal Code	
	Etobicoke			Ontario	M8Z 1V1	
	Name of Licence Ho	lder			1	
	John Lastoria on behalf of Canadian Tire Corporation Ltd.					
	Name of a Senior N	Nanagement person as defined i	in the regulation holding the Record of Train	ning (ROT).	ROT type	
	Glenn Butt				100-08	
,	Municipality (or municipalities if the facility or its hazard distance touches multiple borders)					
1	Toronto					
J.	TOTAL					
	Hours of operation.					
					·	

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information. Declaration: I am aware that it is an offence to give false information in this document and

i nereby deciare that the inform	audii i nave given nei	e is ti de and complete.	
Printname	S	invature	Date (dd-mm-yyyy)
Name of Licence Holder John Lastoria	1	Mater	02/06/11
Name of Licence Floride			
Name of Senior Management person as defined in the			
Regulation holding the Record of Training Glenn Butt			- le



 Technical
 14th Floor - Centre Tower

 Standards and
 3300 Bloor Street West

 Safety Authority
 Toronto Ontario M8X 2X4

 Fax: 416.231.4903

 customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. 2002	Indicate the year of any significant mod none since open	ifications, as defined in s.1, O.Reg 211/01, since establishment.			
Identify the psig rating and serial number for each	dentify the psig rating and serial number for each fixed propane storage tank on site.				
PSIG	Serial Number				
Tank 1: 250 PSIG	D3134.CS4321789OT				
					
Tank 2:		-			
Tank3:		_			
Enter capacity of propane in USWG, fixed, porta	ble, and mobile, and provide detailed i	nventory that includes the number of tank/vessel for			
each type (fixed, portable, and mobile) and the	capacity of each tank/vessel, on a sepa	arate document.			
Fixed: 2000 USWG	Portable: 418 USWG	Mobile:			

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title EH & S Specialist	
Signature Ta Va (E)	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011

FS 09195 (11/10) Page 2 of 1/5



Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority
Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane S	Supplier(s)					
Superior Propane - Ontario Regional Operations Centre						
Town / City or Town Guelph	nship / Country	s s	Province Ontario		Postal Code N1H 8J1	
Telephone No.	Fax No.	Contact Name				
1-877-873-7467	519-836-7766	Mike Mullins				
E-mail mullinsm@superiorpr	opane.com					
Name of Propane 1 Superior Propane - Gr	Transporter. If same as abuelph	ove, please check box.				
Oll Got 110.	Street Name / 911 Number / A Cellington Rd. 124 S	Address, if applicable				
Town / City or Town Guelph	Town / City or Township / Country Guelph Province Ontario Province N1H 6L3					
Telephone No. 519-831-6564	Fax No. N/A	Contact Name Jason Swan				
E-mail swanj@superiorpropane.com						
Off-site Cylinder and/or Mobile Storage Capacity stored off-site, in USWG For Office Use - Party No.						
Street No. Street Name / 911 Number / Address, if applicable						
Town / City or Township / Country Province Postal Code					Postal Code	
Telephone No. Fax No. Contact Name						
	•					

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Kelly Almey	Official Title Risk & Safety Coordinator, Superior Propane		
Signature Kalmen	Telephone No. 905-285-2480 ext. 5549	Date (dd-mm-yyyy) 02/06/2011	
FS 09195 (11/10) Page 3 of 15			



Technical 14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any. Gasoline: The site has 3 underground tanks with a total capacity of 150,000 litres. They are located at the Northwest corner of the gas bar property.
An MSDS for regular unleaded gasoline is provided herein. MSDS for premium gasoline and diesel are similar and not included.
P
Description of fire and emergency equipment indicated on facility site map.
1. Fires Extinguisher Locations: 1. Inside gas bar building 2. On columns by gasoline dispensers 3. At the bulk propane tank filling station
2. Emergency stop push button - mounted on a post near the propane tank. This shuts down the pump and closes a solenoid valve upstream of hoses.
3. Power supply breaker inside the gas bar building. This cuts all power to the propane system - shuts down pump; closes solenoid valve.
List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)
and describe their function, use and operation.
Emergency stop push button - mounted on a post by the propane tank. This shuts down the pump and closes a solenoid valve upstream of hoses.
Fusible link on ISC valve - isolation valve between the tank and the downstream propane dispensing equipment.
3. Power supply breaker inside the gas bar building. This cuts all power to the propane system - shuts down pump; closes solenoid valve.
ISC valve interlock bar (interlocked with cabinet door) - ISC valve closes when door is closed.
Maintenance and testing schedule for fire protection controls and devices.
Maintenance and testing is undertaken by Superior Propane according to Superior Propane's Maintenance Standard. Schedule for key equipment is:
1. Pumps (Pump every 3 months; Pump Motor: check belts monthly; grease motor every 6 months); 2. ISC Valves (test for closure every 6 months)
3. Fusible links - inspected every 6 months; 4. Storage tank Relief Valves - inspect every 2 years; replacement schedule as per provincial regulations.
Maintenance records are kept in a maintenance log at the site and kept for 5 years.
Maintenance records are kept in a maintenance by at the site and kept for 5 years.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Lastoria	EH & S Specialist	
Signature Signature	Telephone No.	Date (dd-mm-yyyy)
Jacob Marie	416-544-7608	02/06/2011

FS 09195 (11/10) Page 4 of 15



FS 09195 (11/10) Page 5 of 15

Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact	5. Facility 24-Hour Contact Person		
Name Vahia Mohamed Saeed For Office Use - Part	In our transition		
Official Title Agent	Official Title Agent		
Telephone No. Fax No. 416-259-2724 416-259-2683	Cell No. Fax No. 416-259-2683		
E-mail 1328.Queensway West@ctpagent.ca	E-mail 1328.Queensway_West@ctpagent.ca		
Role and responsibilities in emergency	Role and responsibilities in emergency		
Coordinate site response	Coordinate site response		
2. Facility Contact Personnel - Alternate Contact	6. Name of Facility Manager		
Name Karl Degeus For Office Use - Part	y No. Name For Office Use - Party No. Yahia Mohamed Saeed		
Official Title Regional Business Manager	Official Title Agent		
Telephone No. Fax No. 289-649-0841	Telephone No. 416-259-2724 Fax No. 416-259-2683		
E-mail karl.degeus@cantire.com	E-mail 1328.Queensway_West@ctpagent.ca		
Role and responsibilities in emergency	Role and responsibilities in emergency		
Coordinate site response if agent unavailable.	Coordinate site response		
3. Local Fire Services - Key Contact	7. Propane Supplier Key Contact Person		
Name For Office Use - Party William A. Stewart	No. Name Superior Propane Hotline For Office Use - Party No.		
Official Title Fire Chief	Official Title		
Telephone No. 416-338-9051 Fax No. 416-338-9060	Telephone No. 1-877-873-7467 Fax No.		
E-mail wstewart@toronto.ca	E-mail		
Role and responsibilities in emergency	Role and responsibilities in emergency		
Coordinate/advise on Toronto Fire Service response and liaise with po and CTC contact.	lice Identify and dispatch Superior Propane and or LPERGC emergency response personnel as required.		
4. Local Fire Services - Alternate Contact	8. Municipal Contact		
Name For Office Use - Particularly Fuglerud	/ No. Name Ulli S. Watkiss		
Official Title Deputy Fire Chief of Operations	Official Title City Clerk		
Telephone No. 416-338-9053 Fax No. 416-338-9060	Telephone No. Fax No. 416-392-8010 416-392-2980		
E-mail dfugleru@toronto.ca	E-mail clerk@toronto.ca		
Role and responsibilities in emergency	Municipality		
Alternate - Coordinate/advise on Toronto Fire Service response and lia with police and CTC contact.	ise City of Toronto		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title EH & S Specialist	
Signature The Tay To e	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011



 Technical
 14th Floor - Centre Tower

 Standards and Safety Authority
 3300 Bloor Street West Toronto Ontario M8X 2X4

 Fax: 416.231.4903
 Fax: 416.231.4903

 customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.				
Emergency Shut Off push button to shut down pump and close solenoid valve upstream of dispensing hoses.				

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please	print) Official T	Official Title	
John Lastoria	EH & S S	pecialist	
Signature	Telephol 416-544-7	State County William State County State Coun	
FS 091,95 (11/10) Page 6 of 15			

Technical Standards and Safety Authori www.tssa.org

| Technical | 14th Floor - Centre Tower | 3300 Bloor Street West | Toronto Ontario M8X 2X4 | Fax: 416.231.4903 | Customer Service: 1.877.682.8772 |

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Re	sponse Plan and Procedures provided to facility key contacts.
Training Date (dd-mm-yyyy)	Print Name of Training Provider: None
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training on the facility's Em	ergency Management Procedures provided to staff.
Training Date (dd-mm-yyyy)	Print Name of Training Provider: None
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
On-site specific training pro	ovided to certificate holders / persons with Records of Training.
Training Date (dd-mm-yyyy)	Print Name of Training Provider: Yahia Mohamed Saeed (Agent)
05/2010	Print Name of Instructor: Yahia Mohamed Saeed (Agent)
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Lastoria	EH & S Specialist	
Signature 57	Telephone No.	Date (dd-mm-yyyy)
for fales	416-544-7608	02/06/2011

FS 09195 (11/10) Page 7 of 15



FS 09195 (11/10) Page 8 of 15

 Technical
 14th Floor - Centre Tower

 Standards and
 3300 Bloor Street West

 Toronto Ontario M8X 2X4
 Fax: 416.231.4903

 www.tssa.org
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Re	esponse Plan and Procedures provided to facility key contacts.
Target Date (dd-mm-yyyy)	Print Name of Training Provider: Superior Propane or alternate
Q4 2011	Print Name of Instructor: to be arranged
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training on the facility's En	nergency Management Procedures provided to staff.
Target Date (dd-mm-yyyy)	Print Name of Training Provider: Key site contact to train staff
Q4 2011	Print Name of Instructor: to be arranged
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
On-site specific training pr	ovided to certificate holders / persons with Records of Training.
Target Date (dd-mm-yyyy)	Print Name of Training Provider: Yahia Mohamed Saeed (Agent)
As required	Print Name of Instructor: Yahia Mohamed Saeed Please note: ROT training and certification is valid for a 3 year period.
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Lastoria	EH & S Specialist	
Signature Harles	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011



Technical 14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4 Fax: 416.231.4903

www.tssa.org Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate). The owner/operator or alternate (both ROT staff) will contact emergency services by calling 911 and will provide warnings as outlined in the attached

Propane Emergency Response Procedures (to be posted at site and be part of employee training). If it is safe to do so, this could involve advising neighbours to evacuate. The owner/operator may also contact Superior Propane via the emergency number identified in the ERP.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

The owner/operator or alternate should first follow the actions in the ERP's provided herein. Staged evacuation, if the release of propane cannot be stopped by cutting electrical power may be required. Initial muster locations will be on the north of store near service centre, at least 120 m from tank and away from a dispersing propane cloud. Subsequent evacuation instructions potentially up to the Hazard Distance to be provided by municipal emergency responders.

Residences and businesses beyond the site boundary to be notified by municipal emergency responders.

Communication with	Emergency Response	Authorities
--------------------	---------------------------	-------------

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

When the system is operational, site staff will be on duty and be in the propane tank area. The Key Contact or alternate will be implementing ER actions and notifications, including notifying emergency responders. Calling 911 will occur immediately after any attempts to shut down the system.

When the system is not in operation, the ISC valve (main isolation valve) is closed, and the propane system is unattended, but is shutdown. Any accidents involving the propane tank during such times will require the intervention of random, nearby individuals.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

The propane tank system is located in a wide open store parking lot area that is easily accessible from The Queensway.

The access routes for fire trucks are identified in the attached site plan.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The critical information required from the license holder is information on how to shut the system down and the fill level in the tank (if known). This will be provided either verbally if site staff are at site or by cell phone during off hours.

Fill level is relevant from a time-to-BLEVE perspective (a near empty tank will BLEVE sooner than a full tank if there is fire impingement on the tank).

How long will it take the facility liaison person to respond to the site. Approximately 30 minutes after having received the emergency call.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Lastoria	EH & S Specialist	
Signature / Lau Co	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011

FS 09195 (11/10) Page of 15



14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

EMERCENCY AND DREDADEDNIEGO DECRONGE DI ANI /

1. Does the propane location have controlled access to limit unnecessary risk and entry (clock out procedures)? 2. Is there adequate night lighting at the site? 3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials? 4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? 6. Are weighing systems validated for accuracy? 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility site? 7. Water Supply Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for friefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)		The licence holder will complete Section B in consultation with the lo 6. Building and Site Security and Procedures			nt a)	
Clock out procedures)?			Yes	No		
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials? 4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? 6. Are weighing systems validated for accuracy? 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., OCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. Yes No 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	1.			\checkmark		
and the grounds are kept clear from unwanted materials? 4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? 6. Are weighing systems validated for accuracy? 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. Yes No 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	2.	Is there adequate night lighting at the site?	✓			
inspection requirements for filling systems and mechanical devices used in the transfer of propane? 5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? 6. Are weighing systems validated for accuracy? 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	3.		√			
overfilled propane cylinders? 6. Are weighing systems validated for accuracy? 7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	4.	inspection requirements for filling systems and mechanical devices used in the	√			
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	5.		\checkmark			
purged and other hazardous materials)? 8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	6.	Are weighing systems validated for accuracy?	\checkmark			
the propane cylinders are filled?(e.g., QCC valves) 9. Is the schedule of maintenance and testing activities retained on site? 7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	7.			√		
7. Water Supply The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	8.		1			
The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	9.	Is the schedule of maintenance and testing activities retained on site?	√			
supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year		7. Water Supply				
supply capabilities that are available based on the propane facility's location. 1. Is a pressurized water system available at the propane facility site? 2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year						
 Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location? What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) What is the unobstructed distance to the closest approved water supply with year 			Yes	No		
location? 3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	1.	Is a pressurized water system available at the propane facility site?	√			
firefighting activities? (distance in metres only) 4. What is the unobstructed distance to the closest approved water supply with year	2.		\checkmark			
	3.		26 metres			
	4.		N/A			

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title EH & S Specialist	
Signature	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011



FS_09195 (1/10) Page 11 of 15

Technical Standards and Safety Authority www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd).

The licence holder will complete Section B in consultation with the local Fire Services.

B: Licence holder and local Fire Services Review.

	Service Services	o norder and to		ARTICLE AND COM	THE RESIDENCE OF THE PARTY SHOWS THE PARTY.
To be completed by the Has the local fire service h	Local Fire Services nad an opportunity to review the	Emergency Re	esponse and Preparedness Plan?	Yes	No
If not, please explain (e.g.	, no fire services).				
Fire services comments, if	fany:				
To be completed by the in response to the above o	Licence Holder comments, the following action((s) is required:			79
	and who gray recommendately the shripping animates in gray specification and state of the state of the state of	uga um bes em albitantes qui difficilità de la companie de la companie de la companie de la companie de la comp			
The licence holder will re	espond to the Local Fire Service	ces comments	by:	dd-mm-yyyy)	
	26				
Action to the second se	=	LOCAL FIRE	SERVICES		
The undersigned has re	eviewed Section B of the Risk	and Safety M	lanagement Plan Fire Services		
Local Fire Services Name	Print name		Signature Julie		Date (dd-mm-yyyy)
18					
ger					
	Declaration: I am aware that it	is an offence to le information i	o give false information in this do have given here is true and comp	cument an olete.	d
Name of person completing	1-1-1		Official Title	3-1-11	~ ~
Signature Signature	ASTORIA		Telephone No.	G C/AL/	Date (dd-mm-vvvv)
Signature	1990		416-544-	7608	57, Date (dd-mm-yyyy) 12-07-2011



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4

Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

- 1. The storage location of fixed, portable, and mobile vessels.
- The maximum volume, types and storage location of hazardous materials.
- 3. Location of permanent structures on site.
- 4. Access and egress points and location of barriers.
- Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
- 6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

- 7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
- 8. GPS co-ordinates of the single largest vessel.
- Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
- 10. Clear indication of the municipality or municipalities present within the circle.
- 11. Visual indication of property line information.
- 12. The location and name of roads within or abutting the site.
- 13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
- 14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
- 15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 02/06/11		Capacity of single largest propane storagevessel (USWG) 2000 USWG		
Tank setback coordinates.	Indicate placement or 12 m (East)	n the map. Right side property line:	178 m (North)	
	97 m (West)	Left side property line:	45 m (South)	
GPS coordinates of single	largest vessel: La	at. 43.6174 , Long79.5447		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title EH & S Specialist	
Signature August 1997	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011

FS 09195 (11/10) Page 12 of 15

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula:

 $D=16.94 \times (1.524 \times C)^{1/3}$

D = Distance to overpressure of 1 psi (meters)

C= Tank Total Capacity in USWG

Parameters:


Density of Propane is 0.5033 kg per litre @ 15 C

Assume all vessels are 80% full

1 gallon [US, liquid] = 0.003785411784 cubic meter

1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Nothing completed on this page.	Official Title			
Signature	Telephone No.	Date (dd-mm-yyyy)		



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2. Table 2: Buildings and Features

	Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")		Distance from Tank to Closest Building or		
	AND Name and Address of Glosest building of Feature	0	1	2-10	11+	Feature
Name:	buildings or parks or golf courses Various Businesses (Just north of The Gardiner Expressway)			x		166 m
Name:	ial building units specifically permanent single family dwellings, condominiums, and apartments.	x				
Name:	cial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Various Retail - Courtesy Chevrolet; Lazy Boy; Taco Bell; Sunoco; Kia Motors; CIBC Province Postal Code				х	19 m
Name:	cial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Province Province Postal Code	X				m
institution Name:	institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health is, and prisons.	×				m
Name:	cy responders specifically fire stations, ambulance stations, and police stations. Province Postal Code	х				

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete

Thereby acolare that the information rileve given here to the and complete.				
Name of person completing this form (please print)	Official Title			
John Lastoria	EH & S Specialist			
Signature	Telephone No.	Date (dd-mm-yyyy)		
the Hales	416-544-7608	02/06/2011		

FS 09195 (11/10) Page 14 of 15

^{*} For multi-unit buildings, count each unit as "1".



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		_
# 30	8.8		
# 20	5.8	72	418 USWG
# 10	2.9		
# 5	1.5		


Tanks Stored On-site Not Connected for Use


Tank Size In USWG	Quantity	Total Volume in USWG	
None 2000 USWG	1	2000 USWG +a	
a a		Kelly Arm	
		2000 USWG KA Kelly All Superior	
		,	
Total Tank Capacity			
Total Cylinder Capacity 418 USWG			
Total Tank Capacity	a 2000 USWG da		
Total Portable Capacity	418 USWG		


Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title EH & S Specialist			
Signature Turk	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 02/06/2011		

FS 09195 (11/10) Page 15 of 15







1612 The Queensway, Etobicoke, ON, M8Z 1V1 March 5, 2011 For Legal Description see attached Word doc. Map of Surrounding Area Date: Canadian Tire Drawn by: L. Oliverio Ulli S. Watkiss City Clerk City of Toronto Toronto City Hall 13th fl.W., 100 Queen St. W Tel: (416) 392-8010 Email: clerk@toronto.ca City of Toronto Denoted by circle centred on tank; radial distance = 246 m Capacity of Propane Storage Tank = 2000 USWG East: 12 m West: 97 m GPS Co-ordinates = 43.61748, -79.54448 North: 178 m South: 45 m

