



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection. Making a false statement may result in a fine or prosecution under the <i>Technical Standards and Safety Act</i>		
Licence Number 0076475268 - C		
Check applicable type of propane operations. <input checked="" type="checkbox"/> Cylinder <input type="checkbox"/> Motor Fill <input type="checkbox"/> Filling Plant <input type="checkbox"/> Card/Keylock Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.		

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

Company Name		Ontario Corporation No., if applicable	
A COLMAN DILLON AUTOMOTIVE LTD.			
Operator Name (if different from above) None			
Telephone No. 519-979-0088	Fax No. 519-979-0092	E-mail cdaoto1111@gmail.com	
B Street No. Street Name / 911 Number / Address, if applicable			
13101		Tecumseh Road.	
Town / City or Township / County Tecumseh		Province Ontario	Postal Code N8N - 3T4
Mailing address if different from above.			
C Street No. Street Name / 911 Number / Address, if applicable			
SAME			
Town / City or Township / County		Province	Postal Code
Information on Container Refill Centre or Filling Plant			
Location of facility.			
D Street No.		Nearest Major Intersection	
13101		Manning Road and Tecumseh Road	
Street Name / 911 Number / Address, if applicable Tecumseh Road			
Town / City or Township / County Tecumseh		Province Ontario	Postal Code N8N - 3T4

Name of Licence Holder COLMAN DILLON AUTOMOTIVE LTD.	
Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). George Dillon	ROT type P.P.O. - 3
Municipality (or municipalities if the facility or its hazard distance touches multiple borders) Tecumseh, Ontario.	
Hours of operation. 	

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name Name of Licence Holder <u>Colman Dillon Automotive Ltd.</u>	Signature 	Date (dd-mm-yyyy) 24 / 09 / 2011
Name of Senior Management person as defined in the Regulation holding the Record of Training <u>George Dillon</u>	ROT # 177 - TTT 00051	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. 1990 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment.
No Significant Modifications.

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	<u>250</u>	<u>697 - 96</u>
Tank 2:	<u>0</u>	<u>0</u>
Tank 3:	<u>0</u>	<u>0</u>

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: (1) - 1000 USWG Portable: 69.6 USWG Mobile: 0



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>JO-ANNE DILLON</u>		Official Title <u>Secretary / Treasurer</u>
Signature <u>Jo-Anne Dillon</u>	Telephone No. <u>519-979-0088</u>	Date (dd-mm-yyyy) <u>24 / 09 / 2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) AABCO PROPANE INC.		For Office Use - Party No.	
Street No. 5475	Street Name / 911 Number / Address, if applicable DiCocco Court		
Town / City or Township / Country Oldcastle		Province Ontario	Postal Code NOR - 1L0
Telephone No. 519-737-9635	Fax No. 519-737-9137	Contact Name Andy Burton	
E-mail a.burton@aabcopropane.com			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>		For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage NONE	Capacity stored off-site, in USWG	For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer
Signature <i>Jo Anne Dillon</i>	Telephone No. 519-979-0088
	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Oxygen & Acetylene Welding Tanks - on a transportable cart - Located in the Shop Area (shown in picture on page 19).

This facility is a distributor for PRAXAIR - all tanks stored are secured by chain (shown in picture on page 19).

PRAXAIR Tanks stored are as follows; - NITROGEN, HELIUM, ARGON, CARBON DIOXIDE, ACETYLENE, and OXYGEN.

Description of fire and emergency equipment indicated on facility site map.

Fire and Emergency Equipment on site are - Fire Extinguishers Only. There are (6) extinguishers at facility - noted on site drawing (page 12)

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

There are no additional Fire Protection Controls at this Facility. Emergency notification initiated via "air horn".

There is an INTRUSION ALARM - Monitored by Guardian Alarm. Guardian Alarm's Emergency Contact Number is 519-977-5629

Maintenance and testing schedule for fire protection controls and devices.

All Fire Protection Equipment on site is Inspected, Tagged, and Recorded by contracted 3rd party - Inspections are completed annually.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature 	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name Jo-Anne Dillon	For Office Use - Party No.	Name Jo-Anne Dillon / George Dillon	For Office Use - Party No.
Official Title Secretary / Treasurer		Official Title Co-Owners	
Telephone No. 519-979-0088	Fax No. 519-979-0092	Cell No. 519-792-9962	Fax No. 519-979-0092
E-mail cdauto1111@gmail.com		E-mail cdauto1111@gmail.com	
Role and responsibilities in emergency Emergency Response Liason		Role and responsibilities in emergency Emergency Response Liasons	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name George Dillon	For Office Use - Party No.	Name Moisse Chauvin	For Office Use - Party No.
Official Title Owner		Official Title Manager	
Telephone No. 519-979-0088	Fax No. 519-979-0092	Telephone No. 519-792-4512 (cell)	Fax No. 519-979-0092
E-mail cdauto1111@gmail.com		E-mail None Available	
Role and responsibilities in emergency Emergency Response Liason		Role and responsibilities in emergency Emergency Response Liason	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name Doug Pitre	For Office Use - Party No.	Name Andy Burton	For Office Use - Party No.
Official Title Fire Chief		Official Title Aabco Propane Inc. - Owner	
Telephone No. 519-979-4041 ext. 10	Fax No. 519-979-5881	Telephone No. 519-737-9635	Fax No. 510-737-9137
E-mail dpitre@tecumseh.ca		E-mail a.burton@aabcopropane.com	
Role and responsibilities in emergency Incident Command		Role and responsibilities in emergency Propane Advisor	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name Art Lounsbury	For Office Use - Party No.	Name Laura Moy	For Office Use - Party No.
Official Title Deputy Fire Chief		Official Title Town Clerk / Director of Staff Services	
Telephone No. 519-979-4041	Fax No. 519-979-5881	Telephone No. 519-735-2184 ext. 116	Fax No. 519-735-6712
E-mail alounsbury@tecumseh.ca		E-mail lmoy@tecumseh.ca	
Role and responsibilities in emergency Alternate Incident Command		Municipality Town of Tecumseh	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer
Signature 	Telephone No. 519-979-0088
	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

There are currently no measures that exceed the Minimum Codes or Standards.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature <i>Jo-Anne Dillon</i>	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) 12 / 10 / 2011	Print Name of Training Provider: Emergency Response Training - EPC Services
	Print Name of Instructor: Raymond Roy
Training Date (dd-mm-yyyy) 24 / 11 / 2011	Print Name of Training Provider: Aabco Propane Inc. - Emergency Evacuation / Fire Extinguisher Training
	Print Name of Instructor: Paul Lauzon
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) 12 / 10 / 2011	Print Name of Training Provider: Emergency Response Training - EPC Services
	Print Name of Instructor: Raymond Roy
Training Date (dd-mm-yyyy) 24 / 11 / 2011	Print Name of Training Provider: Aabco Propane Inc. - Emergency Evacuation / Fire Extinguisher Training
	Print Name of Instructor: Paul Lauzon
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 30 / 12 / 2009	Print Name of Training Provider: Aabco Propane Inc. - Propane Certificate Training
	Print Name of Instructor: Andy Burton
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer
Signature <i>Jo Anne Dillon</i>	Telephone No. 519-979-0088
	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) 09 / 01 / 2012	Print Name of Training Provider: Colman Dillon - Risk & Safety Management Plan Training
	Print Name of Instructor: Jo-Anne Dillon
Target Date (dd-mm-yyyy) 24 / 11 / 2012	Print Name of Training Provider: Aabco Propane Inc - Emergency Evacuation / Fire Extinguisher Training
	Print Name of Instructor: Paul Lauzon
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) 09 / 01 / 2012	Print Name of Training Provider: Colman Dillon - Risk & Safety Management Plan Training
	Print Name of Instructor: Jo-Anne Dillon
Target Date (dd-mm-yyyy) 24 / 11 / 2012	Print Name of Training Provider: Aabco Propane Inc - Emergency Evacuation / Fire Extinguisher Training
	Print Name of Instructor: Paul Lauzon
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) 30 / 12 / 2012	Print Name of Training Provider: Aabco Propane Inc. - Propane Specific Training
	Print Name of Instructor: Andy Burton
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer
Signature 	Telephone No. 519-979-0088
	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).

The licence holder on site will notify customers, contractors and employees of an emergency via "air horn" warnings. The manager will immediately call 911.

The Incident Commander on scene will assess the situation and will evacuate and move the occupants of the surrounding area to the appropriate distances.

There are additional air horns located throughout the facility and are to be used for evacuation purposes only. All staff are trained annually in Emergency Response.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

The manager or supervisor on site will notify the customers, contractors and employees verbally. There is an identified evacuation area noted on (page 18).

All those employees and contractors on site will be instructed to report and assemble at these areas in the event of a propane situation.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

The licence holder or designate will call 911 in the event of an emergency. The call will be made from the facility phone or a cell phone carried by the owner or manager both on and off site.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

The propane tank is accessible from either an east or west directions off of Tecumseh Road.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The licence holder or designated Emergency Response Liaison will be available to the Local Fire Department as directed on page #7 of the Emergency Response Document. RSMP will be available to First Responders.

How long will it take the facility liaison person to respond to the site.

Licence Holder / Emergency Liaison will be on site 10 minutes after receiving call from Emergency Officials.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon		Official Title Secretary / Treasurer
Signature 	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<u>34.9 m</u>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<u>NONE</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature 	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes	No
<input checked="" type="checkbox"/>	<input type="checkbox"/>

If not, please explain (e.g., no fire services).

Fire services comments, if any:

(See Attached Letter)

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

Licence Holder will work with Tecumseh Fire to address all issues identified within 60 days.

The licence holder will respond to the Local Fire Services comments by: 25 / 11 / 2011
(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name FIRE CHIEF DOUG PITRE		12 / 10 / 2011

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature <i>Jo Anne Dillon</i>	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011

Tecumseh Fire/Rescue Services

Mailing Address
917 Lesperance Road
Tecumseh, Ontario
N8N 1W9

MAYOR – MAIRE
GARY McNAMARA

DEPUTY MAYOR – SOUS MAIRE
CHERYL HARDCASTLE

COUNCILLORS - CONSEILLERS
JOE BACHETTI
MARCEL BLAIS
GUY DORION
TANIA JOBIN
RITA OSSINGTON



Administrative Offices
985 Lesperance Road
Tecumseh, Ontario
N8N 1W9

FIRE CHIEF
DOUG PITRE

DEPUTY FIRE CHIEF

**ASSISTANT FIRE CHIEF/FIRE
PREVENTION OFFICER**
BOB HAMILTON

Telephone (519) 979-4041
Facsimile (519) 979-5881
Emergency Telephone 911

October 12, 2011

E.P.C. Services
3549 Byng Road
Windsor, Ontario
N8W 3H7

Attention: Mr. Raymond Roy, Consultant

Dear Mr. Roy:

Re: TSSA – RSMP Level 1/Reg. 211/01 – Colman Dillon Automotive Ltd.

In response to your submission dated September 24, 2011, the Administration of the Tecumseh Fire Rescue Services has the following concerns with respect to the TSSA – RSMP Level 1/Reg. 211/01 as they pertain to Colman Dillon Automotive Ltd. located at 13101 Tecumseh Road in Tecumseh.

1. Dispensing cabinet is not secured from the public during the day.
2. Page 28 Circuit Protection. Photo on Page 18 shows access to electrical panels obstructed by table and other materials. Electrical Code requires one meter clearance in front of electrical panel. There was no requirement for an emergency shut-off switch at the time of installation of the propane. The circuit breaker is the only way to shut power to the propane system.
3. Page 16 shows PFE inside cabinet. For ease of access during an emergency, mount on inside of cabinet door.
4. When transfers are conducted by supplier, are there procedures to follow by certified attendants or owner that assure safety measures are in place prior to transferring product.

Yours truly,

TECUMSEH FIRE AND RESCUE SERVICES

Doug Pitre
Fire Chief

DP:ld

Fire Prevention is Everybody's Business



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) <u>10 / 09 / 2011</u>	Capacity of single largest propane storage vessel (USWG) <u>1000 USWG</u>
Tank setback coordinates. Indicate placement on the map.	
Front: <u>4.0 meters</u>	Right side property line: <u>21.8 meters</u>
Rear: <u>87.2 meters</u>	Left side property line: <u>3.6 meters</u>
GPS coordinates of single largest vessel: <u>82°52'21.9" W</u> <u>42°18'43.3 N</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Jo-Anne Dillon</u>	Official Title <u>Secretary / Treasurer</u>	
Signature 	Telephone No. <u>519-979-0088</u>	Date (dd-mm-yyyy) <u>24 / 09 / 2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature <i>Jo Anne Dillon</i>	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				X _____ m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. Name: _____ Address: _____ City: _____				X	50.8 _____ m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____			X		110.7 _____ m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				X _____ m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				X _____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				X _____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon	Official Title Secretary / Treasurer	
Signature <i>Jo-Anne Dillon</i>	Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9	0	0
# 100	29.5	0	0
# 40	11.75	0	0
# 33.3	9.62	0	0
# 30	8.8	0	0
# 20	5.8	12	69.6 USWG
# 10	2.9	0	0
# 5	1.5	0	0
Total Cylinder Capacity	69.6 USWG		

Tanks Stored On-site Not Connected for Use


Tank Size In USWG	Quantity	Total Volume in USWG
0	0	0
Total Tank Capacity	0	

Total Cylinder Capacity	69.6 USWG
Total Tank Capacity	0
Total Portable Capacity	69.6 USWG

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jo-Anne Dillon		Official Title Secretary / Treasurer	
Signature <i>Jo-Anne Dillon</i>		Telephone No. 519-979-0088	Date (dd-mm-yyyy) 24 / 09 / 2011

2.1 COLMAN DILLON AUTOMOTIVE LTD. – HAZARD DISTANCE – (195 METERS)



PROPANE TANK LOCATION


13101 TECUMSEH RD. E.
TECUMSEH ONTARIO
1000 USWG

TANK LOCATION

82* 52' 21.9"W
42* 18' 43.3" N

EMERGENCY EVACUATION AREA

2.2 HYDRANT LOCATIONS



Location – Lesperance Road

Prepared – September 10, 2011
1000 USWG – VERTICAL

Tank Setbacks – Property Lines

Front – 4.0 meters
Right – 21.8 meters
Left – 3.6 meters
Rear – 87.2 meters

Radius @ 195 meters


Municipality – Tecumseh Ontario

Director, Staff Services / Clerk
Laura Moy
519-735-2184
lmoy@tecumseh.ca
Town of Tecumseh, Ontario

MSDS / DATA SHEETS


Are kept in the management offices.








2.3 SITE DRAWINGS / EVACUATION ROUTES






COLMAN DILLON AUTOMOTIVE
13101 TECUMSEH RD. EAST
TECUMSEH, ONTARIO



-  AIR HORN
-  FIRE EXTINGUISHER
-  ELECTRICAL SHUT OFF
-  GAS SHUT OFF
-  STAIRS TO MEZZANINE LEVEL
-  STORAGE FOR PRAXAIR TANKS
-  USED MOTOR OIL

DRAWING: EPC SERVICES
September 11, 2011



TECUMSEH ROAD EAST