



Technical Standards and Safety Authority  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

This Level 1 RSMP applies to:   
 • a facility with a total propane storage capacity of 5,000 USWG or less; or  
 • a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection. Making a false statement may result in a fine or prosecution under the *Technical Standards and Safety Act*

Licence Number: 76646726

Check applicable type of propane operations.

Cylinder     Motor Fill     Filling Plant     Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



**SECTION A: GENERAL INFORMATION**

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

**A** Company Name: A1 Petro Biz Inc. Ontario Corporation No., if applicable: \_\_\_\_\_  
 Operator Name (if different from above): \_\_\_\_\_  
 Telephone No.: 416-749-5700/5151 Fax No.: 416-749-1275 E-mail: aveel\_h@live.com

**B** Street No.: 2922 Street Name / 911 Number / Address, if applicable: Islington Ave.  
 Town / City or Township / County: North York Province: Ontario Postal Code: M9L 2K4

Mailing address if different from above.  
**C** Street No.: Same Street Name / 911 Number / Address, if applicable: \_\_\_\_\_  
 Town / City or Township / County: \_\_\_\_\_ Province: \_\_\_\_\_ Postal Code: \_\_\_\_\_

**Information on Container Refill Centre or Filling Plant**

**D** Location of facility.  
 Street No.: 2922 Street Name / 911 Number / Address, if applicable: Islington Ave. Nearest Major Intersection: Islington Ave & Round Tree Mill Road  
 Town / City or Township / County: North York Province: Ontario Postal Code: M9L 2K4

Name of Licence Holder: A1 Petro Biz Inc.

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT): Avtar Singh Bhullar ROT type: \_\_\_\_\_

Municipality (or municipalities if the facility or its hazard distance touches multiple borders): City of Toronto

Hours of operation:

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name Name of Licence Holder: A1 Petro Biz Inc.	Signature <i>Avtar Singh Bhullar</i>	Date (dd-mm-yyyy) 11-01-2012
Name of Senior Management person as defined in the Regulation holding the Record of Training: Avtar Singh Bhullar	<i>Avtar Singh Bhullar</i>	11-01-2012

*Just 963 5695*



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
Propane Storage and Handling Regulation

**SECTION A: GENERAL INFORMATION (cont'd)**


Indicate the year the facility was established. 1989      Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. 1995

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank1:	<u>250</u>	<u>5421-JA</u>
Tank2:	_____	_____
Tank3:	_____	_____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 USWG      Portable: 139.2 USWG      Mobile: 0



**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) <u>Avtar Singh Bhullar</u>		Official Title <u>Owner</u>
Signature <u>Avtar Singh Bhullar</u>	Telephone No. <u>416-749-5700</u>	Date (dd-mm-yyyy) <u>11-01-2012</u>



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
Propane Storage and Handling Regulation

**SECTION A: GENERAL INFORMATION (cont'd)**

Activity Information

<b>Name of Propane Supplier(s)</b> Superior Propane - Regional Operation Centre			For Office Use - Party No.		
Street No. 251	Street Name / 911 Number / Address, if applicable Woodland Road East Unit 217				
Town / City or Township / Country Guelph			Province On	Postal Code N1H 8J1	
Telephone No. 877-873-7467	Fax No. 519-836-7766	Contact Name Mike Mullins			
E-mail mullinsm@superiorpropane.com					

<b>Name of Propane Transporter.</b> If same as above, please check box. <input type="checkbox"/>			For Office Use - Party No.		
Superior Propane					
Street No. 7022	Street Name / 911 Number / Address, if applicable Wellington Road 124 s				
Town / City or Township / Country Guelph			Province On	Postal Code N1H 6L3	
Telephone No. 519-831-6564	Fax No. 519-836-7766	Contact Name Jason Swan			
E-mail swanj@superiorpropane					

<b>Off-site Cylinder and/or Mobile Storage</b> None		Capacity stored off-site, in USWG		For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable				
Town / City or Township / Country			Province	Postal Code	
Telephone No.	Fax No.	Contact Name			

Note: Customer storage is not considered off-site storage.

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar		Official Title Owner	
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700	Date (dd-mm-yyyy) 11-01-2012	





**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN**

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Gasoline 90800 litres - under ground tank

Diesel 25000 litres - under ground tank

Description of fire and emergency equipment indicated on facility site map.

ABC Fire extinguisher

1- 1 - ABC fire extinguisher located at the Propane Dispenser.

2- 1 - ABC fire extinguisher located at gas bar

3- 2 - ABC fire extinguisher located at the gas pumps

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

1- Fusible link on ISC - isolation valve between the tank and the downstream propane dispensing equipment.

2. Emergency Stop Button - at propane dispenser location. This shuts down the pump and closes a solenoid valve upstream of hoses.

3. Power supply breaker inside the main building. This cuts all power to the propane system - shuts down pump; closes solenoid valve.

Maintenance and testing schedule for fire protection controls and devices.

Maintenance and testing is undertaken by Superior Propane according to Superior 's Maintenance Standards. Schedule for key equipment is:

1- Pumps - (pumps every 3 months; pump motor: check belts monthly; grease pump every 6 months).

2- ISC valve (test for closure every 6 months).

3- Storage tank Relief Valves - inspected every 2 years; replacement schedule as per provincial regulations.

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar		Official Title Owner
Signature 	Telephone No. 416-749-5700	Date (dd-mm-yyyy) 11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

1. Contacts for Emergency Response

<b>1. Facility Contact Personnel - Key Contact</b>		<b>5. Facility 24-Hour Contact Person</b>	
Name Avtar Singh Bhullar	For Office Use - Party No.	Name Avtar Singh Bhullar	For Office Use - Party No.
Official Title Owner		Official Title Owner	
Telephone No. 416-749-5151 / 416-624-4234	Fax No. 416-749-1275	Cell No. 416-624-4234	Fax No. 416-749-1275
E-mail avneet_b@live.com		E-mail avneet_b@live.com	
Role and responsibilities in emergency Co-ordinate site response plan (ERP)		Role and responsibilities in emergency Co-ordinate site response plan (ERP)	
<b>2. Facility Contact Personnel - Alternate Contact</b>		<b>6. Name of Facility Manager</b>	
Name Varinder Bhullar	For Office Use - Party No.	Name Avtar Singh Bhullar	For Office Use - Party No.
Official Title Owner		Official Title Owner	
Telephone No. 416-749-5151 / 416-953-8575	Fax No. 416-749-1275	Telephone No. 416-749-5151 / 416-953-8575	Fax No. 416-749-1275
E-mail avneet_b@live.com		E-mail avneet_b@live.com	
Role and responsibilities in emergency Co-ordinate site response plan (ERP)		Role and responsibilities in emergency Co-ordinate site response plan (ERP)	
<b>3. Local Fire Services - Key Contact</b>		<b>7. Propane Supplier Key Contact Person</b>	
Name Frank Lamie	For Office Use - Party No.	Name Superior Propane Hot Line	For Office Use - Party No.
Official Title Deputy Fire Chief - Prevention		Official Title	
Telephone No. 416-338-9054	Fax No. 416-338-9060	Telephone No. 877-873-7467	Fax No. N/A
E-mail flamie@toronto.ca		E-mail n/a	
Role and responsibilities in emergency Co-ordinate emergency response / advise on Fire Service Response. Liaise with police.		Role and responsibilities in emergency Identify and dispatch Superior Propane and or LPGERC emergency response personal as required	
<b>4. Local Fire Services - Alternate Contact</b>		<b>8. Municipal Contact</b>	
Name Jim Stoops	For Office Use - Party No.	Name Ulli Watkiss	For Office Use - Party No.
Official Title Division Chief		Official Title City Clerk	
Telephone No. 416-338-9102	Fax No. 416-338-9060	Telephone No. 416-392-8010	Fax No. 416-392-2980
E-mail jstoops@toronto.ca		E-mail clgrr@toronto.ca	
Role and responsibilities in emergency Co-ordinate emergency response when key contact is not available and Liaise with police services.		Municipality City of Toronto	

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

Emergency Stop Button cuts the power to the dispenser located at the Propane tank. shutting down the solenoid stopping the flow of propane

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar		Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700	Date (dd-mm-yyyy) 11-01-2012





**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) None	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) None	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 20-06-2010	Print Name of Training Provider: Superior Propane	Please Note - a ROT is valid for 3 years
	Print Name of Instructor: Reg Adamson	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) Q1-2012	Print Name of Training Provider: Superior Propane or Alternate	Please note: Canadian Propane Gas Association
	Print Name of Instructor: to be arranged	is currently developing the course
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	content and it and its provider should be available to
	Print Name of Instructor:	teach in the fourth quarter of this year.
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) Q1-2012	Print Name of Training Provider: Key Contact to train staff
	Print Name of Instructor: to be arranged
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) Q7-2013	Print Name of Training Provider: Superior Propane	Please Note - a ROT is valid for 3 years
	Print Name of Instructor: Reg Adamson	Owner to call if training is required in 2011
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012





**Technical Standards and Safety Authority**

www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
**Technical Standards and Safety Act**  
**Propane Storage and Handling Regulation**

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

The licence holder will complete Section B in consultation with the local Fire Services.

**5. Emergency Response Communications Plan**

**Warnings and Actions**

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).  
The operator or Alternate will contact emergency services by calling 911 and will provide warnings outlined in the attached: "Propane Emergency Response Procedures" placard (to be posted on site and part of the employee training). If it is safe to do so this could involve advising neighbors to evacuate. The owner/operator may also contact Superior Propane via the emergency number identified in the ERP.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

The owner /operator or alternate should first follow the actions in the ERP provided herein. Stage evacuation, if the release of propane cannot be stopped by cutting electrical power may be required. Note a specific muster point is not advisable, since a propane plume can blow in any direction.

Actions will be taken by an on duty ROT person(s)

**Communication with Emergency Response Authorities**

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

When the system is operational, a ROT person will be on duty and be in the propane tank area. This person will be able to visually ascertain any abnormal/ accident event and implement the appropriate emergency response actions. When the system is not in operation, the ISC valve (main isolation valve) is closed, and the propane system is unattended. Any accident involving the propane tank during such times will require the intervention of random, nearby individuals.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

The propane tank system is located in a wide open area that is easily accessible.

The fire access routes are identified in the attached site plan.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The critical information required from the license holder is (a) how to shut the system down and (b) the fill level in the tank (if known)

Fill level is relevant from a time-to-BLEVE perspective (a near empty tank will BLEVE sooner than a full tank if there is a fire impingement on the tank).

This information will be provided to the authorities by site Owner Avtar Singh Bhullar or alternate.

How long will it take the facility liaison person to respond to the site.

Lives on site, will take 5 minutes to respond to a emergency

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner	
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700	Date (dd-mm-yyyy) 11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<u>24.384m fire hydrant</u>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? ( distance in metres only)	<u>N/A</u>	

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature <i>Avtar Singh Bhullar</i>	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012





Technical Standards and Safety Authority  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)  
Technical Standards and Safety Act  
Propane Storage and Handling Regulation

**SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)**

The licence holder will complete Section B in consultation with the local Fire Services.

**B. Licence holder and local Fire Services Review**

**To be completed by the Local Fire Services**

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes

No

If not, please explain (e.g., no fire services).

Fire services comments, if any.

**To be completed by the Licence Holder**

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by:

(dd-mm-yyyy)

**LOCAL FIRE SERVICES**

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Local Fire Services Name	Print name <b>SAM COLAVITA</b>	Signature 	Date (dd-mm-yyyy) <b>08/11/2011</b>
--------------------------	-----------------------------------	---------------	----------------------------------------

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature <b>Avtar Singh Bhullar</b>	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) <b>2 Nov 2011</b>

• 2922 1 SLINGTON AVE.  
NORTH YORK.





**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION C: SUBMISSIONS**

Applicant must include a Facility Site Plan and Map of Surrounding Area

**Facility Site Plan.**

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

**Map of Surrounding Area.**

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

**Required Mapping Information from Updated Site Plan**

Date Map Prepared (dd-mm-yyyy)	Capacity of single largest propane storage vessel (USWG)
11-01-2012	2000 USWG
Tank setback coordinates. Indicate placement on the map.	
Front: <u>5.6 m</u>	Right side property line: <u>5.8 m</u>
Rear: <u>26.4 m</u>	Left side property line: <u>53.5 m</u>
GPS coordinates of single largest vessel: <u>Lat: 43 45'21.73" Long: 70 34'9.84"W</u>	

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
J. Ross Keys	Consultant	
Signature	Telephone No.	Date (dd-mm-yyyy)
	416-526-1405	11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION C: SUBMISSIONS (cont'd)**

Applicant must include a Facility Site Plan and Map of Surrounding Area


**Table 1: Distance Table**

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

**Formula:**  $D = 16.94 \times (1.524 \times C)^{1/3}$   
 D = Distance to overpressure of 1 psi (meters)  
 C = Tank Total Capacity in USWG

**Parameters:** Density of Propane is 0.5033 kg per litre @ 15 C  
 Assume all vessels are 80% full  
 1 gallon [US, liquid] = 0.003785411784 cubic meter  
 1 cubic metre = 264.17 USWG

**Hazard Distance Chart (EPA-TNT model)**



**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012



**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION C: SUBMISSIONS (cont'd)**

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

**Table 2: Buildings and Features**

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. [Redacted]				X	40 m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>IDA Pharmacy (St. Joseph Pharmacy)</u> Address: <u>2930 Islington Avenue</u> City: <u>Etobicoke</u> Province <u>Ontario</u> Postal Code <u>M9L 2K5</u>				X	30 m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				0 m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				0 m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				0 m

\* For multi-unit buildings, count each unit as "1".

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) <u>J. Ross Keys</u>	Official Title <u>Consultant</u>
Signature 	Telephone No. <u>416-526-1405</u> Date (dd-mm-yyyy) <u>11-01-2012</u>





**Technical Standards and Safety Authority**  
www.tssa.org

14th Floor - Centre Tower  
3300 Bloor Street West  
Toronto Ontario M8X 2X4  
Fax: 416.231.4903  
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP)**  
*Technical Standards and Safety Act*  
Propane Storage and Handling Regulation

**SECTION C: SUBMISSIONS (cont'd)**

Applicant must include a Facility Site Plan and Map of Surrounding Area

**Portable Storage Additional Information Sheet**

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9	0	0
# 100	29.5	0	0
# 40	11.75	0	0
# 33.3	9.62	0	0
# 30	8.8	0	0
# 20	5.8	24	139.2
# 10	2.9	0	0
# 5	1.5	0	0
<b>Total Cylinder Capacity</b>			139.2

**Tanks Stored On-site Not Connected for Use**

Tank Size In USWG	Quantity	Total Volume in USWG
0	0	0
<b>Total Tank Capacity</b>		0


<b>Total Cylinder Capacity</b>	139.2
<b>Total Tank Capacity</b>	2000 USWG Propane refill tank
<b>Total Portable Capacity</b>	139.2

**Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Avtar Singh Bhullar	Official Title Owner
Signature Avtar Singh Bhullar	Telephone No. 416-749-5700
	Date (dd-mm-yyyy) 11-01-2012







**NOTES:**

CONSEQUENCE OF FAILURE TO AN OVERPRESSURE LEVEL OF 1 BAR AND SAFETY MANAGEMENT PLAN HAS BEEN OBTAINED FOR THE IMPLEMENTATION OF THE PERMITS AND SAFETY MANAGEMENT PLAN

$$D = 17 \times (0.1 \times W \times H)^{1/2} = 24.6m$$

PROPERTY LINE DIMENSIONS
NORTH 5.5m
SOUTH 5.5m
EAST 5.5m
WEST 24.6m

GPS COORDINATES
LATITUDE: 43°42'12.7"N
LONGITUDE: 79°3'5.34"W

AS PER TESA GUIDELINES FOR THE IMPLEMENTATION OF THE PERMITS AND SAFETY MANAGEMENT PLAN, THIS FACILITY ONLY REQUIRES A PERMITS AND SAFETY MANAGEMENT PLAN.

**PLANNING ADVISORY INCORPORATION:**

AS PER TESA ADVISORY REQUIREMENTS, THE FOLLOWING PLANNING INFORMATION IS REQUIRED TO BE PROVIDED TO THE PLANNING ADVISORY INCORPORATION (PAI) FOR REVIEW AND COMMENT:

- 2 FLOOR CONCEPT DRAWING
- 2 FLOOR CONCEPT ADJUSTED
- MAC S&S
- ATP: UN, TOA, HSETE
- PHSP: 4102912511

NO.	DATE	DESCRIPTION	APP.
0	JUN 12, 12	ISSUED FOR PERMITS AND SAFETY MANAGEMENT PLAN	

**A1 PETRO BIZ**



Alternative Energy Consulting

Telephone: (905) 944-1544 Fax: (905) 944-5899

1100 Sheppard Ave. E. Unit 204

Markham, ON L3R 9V4

Project Name: A1 PETRO BIZ

Client: A1 PETRO BIZ

Project No: 120100

Scale: 1:200

Drawn By: JUC

Checked By: JUC

Issue Date: JUN 11, 12

Issue Time: 13:00

Issue Location: A1 PETRO BIZ

Issue File: 120100-120

Issue Date: D

Issue Time: 14

Issue Location: A1

Issue File: 120100