



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection.
Making a false statement may result in a fine or prosecution
under the *Technical Standards and Safety Act*

Licence Number 000076646684

Check applicable type of propane operations:

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

Company Name Canadian Tire Corporation Ltd. Ontario Corporation No., if applicable _____

A Operator Name (if different from above)
Chris Berthiaume (Agent)...519-736-2040

Telephone No. (416) 544-7608 Fax No. (416) 544-6163 E-mail john.lastoria@canlire.com

B Street No. 1280 Street Name / 911 Number / Address, if applicable Yonge Street, 17th Floor

Town / City or Township / County Toronto Province Ontario Postal Code M4P 2V8

Mailing address if different from above.

C Street No. _____ Street Name / 911 Number / Address, if applicable PO Box 770, Station K (Account #34421)

Town / City or Township / County Toronto Province Ontario Postal Code M4P 3J5

Information on Container Refill Centre or Filling Plant

D Location of facility.

Street No. 421 Street Name / 911 Number / Address, if applicable Sandwich Street South Nearest Major Intersection Sandwich Street & Pickering Drive

Town / City or Township / County Amherstburg Province Ontario Postal Code N9V 3K8

Name of Licence Holder John Lastoria on behalf of Canadian Tire Corporation

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). Glenn Butt ROT type 100-0B

Municipality (or municipalities if the facility or its hazard distance touches multiple borders)
Town of Amherstburg

Hours of operation.

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Printname	Signature	Date (dd-mm-yyyy)
Name of Licence Holder <u>John Lastoria</u>		<u>16-11-2011</u>
Name of Senior Management person as defined in the Regulation holding the Record of Training <u>Glenn Butt</u>		<u>For Glenn</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. 2007 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. None since opening

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	<u>250 PSIG</u>	<u>517-05</u>
Tank 2:	_____	_____
Tank 3:	_____	_____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 USWG Portable: 279 USWG Mobile: 0



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>John Lastoria</u>	Official Title <u>E H & S Specialist</u>	
Signature 	Telephone No. <u>416-544-7608</u>	Date (dd-mm-yyyy) <u>16-11-2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s)			
Superior Propane - Ontario Regional Operations Centre			
Street No.	Street Name / 911 Number / Address, if applicable		
251	Woodlawn Road West, Unit 217		
Town / City or Township / Country			Postal Code
Guelph			N1H 8J1
Telephone No.	Fax No.	Contact Name	
1-877-873-7467	519-836-7766	Mike Mullins	
E-mail			
mullinsm@superiorpropane.com			

Name of Propane Transporter. If same as above, please check box. <input type="checkbox"/>			
Superior Propane - Chatham			
Street No.	Street Name / 911 Number / Address, if applicable		
7652	Queensline Highway 2 West		
Town / City or Township / Country			Postal Code
Chatham			N7M 5J5
Telephone No.	Fax No.	Contact Name	
519-401-1095	N/A	Mike Mullins	
E-mail			
mullinsm@superiorpropane.com			

Off-site Cylinder and/or Mobile Storage	Capacity stored off-site, in USWG	For Office Use - Party No.
None		
Street No.	Street Name / 911 Number / Address, if applicable	
Town / City or Township / Country	Province	Postal Code
Telephone No.	Fax No.	Contact Name

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Latoria	E H & S Specialist	
Signature	Telephone No.	Date (dd-mm-yyyy)
	416-544-7608	16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Gasoline - The site has underground tanks with a total capacity of 175,000 litres. They are located north of the gasoline dispensers.

An MSDS for regular unleaded gasoline is provided herein. MSDS for premium gasoline and diesel are similar and not included.

Description of fire and emergency equipment indicated on facility site map.

1. Fires Extinguisher Locations: a) Inside gas bar building b) On columns by gasoline dispensers c) At the bulk propane tank filling station
2. Emergency stop push button - near kiosk. This shuts down the pump and closes a solenoid valve upstream of hoses.
3. Power supply breaker inside the gas bar building. This cuts all power to the propane system - shuts down pump; closes solenoid valve.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

1. Emergency stop push button. This shuts down the pump and closes a solenoid valve upstream of hoses.
2. Fusible link on ISC valve - isolation valve between the tank and the downstream propane dispensing equipment.
3. Power supply breaker inside the gas bar building. This cuts all power to the propane system - shuts down pump; closes solenoid valve
4. ISC valve interlock bar (interlocked with cabinet door) - ISC valve closes when door is closed.

Maintenance and testing schedule for fire protection controls and devices.

Maintenance and testing is undertaken by Superior Propane according to Superior Propane's Maintenance Standard. Schedule for key equipment is:

1. Pumps (Pump every 3 months; Pump Motor: check belts monthly; grease motor every 6 months); 2. ISC Valves (test for closure every 6 months)
3. Fusible links - inspected every 6 months; 4. Storage tank Relief Valves - inspect every 2 years; replacement schedule as per provincial regulations.
5. Fire extinguishers maintained by Canadian Tire in accordance with Ontario fire regulations. Maintenance records are kept for 5 years.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact

Name Chris Berthiaume		
Official Title Agent		
Telephone No. 519-736-2040	Fax No. 519-736-2040	
E-mail 1522.amherstburg.ctpagent.ca		
Role and responsibilities in emergency Coordinate site response		

5. Facility 24-Hour Contact Person

Name Chris Berthiaume	For Office Use - Party No.
Official Title Agent	
Cell No. 519-919-6045	Fax No. 519-736-2040
E-mail 1522.amherstburg.ctpagent.ca	
Role and responsibilities in emergency Coordinate site response	

2. Facility Contact Personnel - Alternate Contact

Name Jackie Lacroix	For Office Use - Party No.
Official Title Regional Business Manager	
Telephone No. 519-272-3610	Fax No. 519-272-1893
E-mail Jackie.lacroix@cantire.com	
Role and responsibilities in emergency Coordinate site response if agent is unavailable	

6. Name of Facility Manager

Name Chris Berthiaume	For Office Use - Party No.
Official Title Agent	
Telephone No. work:519-736-2040 cell:519-919-6045	Fax No. 519-736-2040
E-mail 1522.amherstburg.ctpagent.ca	
Role and responsibilities in emergency Coordinate site response	

3. Local Fire Services - Key Contact

Name Randy Sinasac	For Office Use - Party No.
Official Title Fire Chief	E-mail rsinasac@amherstburg.ca
Telephone No. 519-736-6500	Fax No. 519-736-5403
Role and responsibilities in emergency Coordinate/advise on Fire Service response and liaise with police and CTC contact.	
Fire Services Address 271 Sandwich St. South Amherstburg, ON N9V 2A5	

7. Propane Supplier Key Contact Person

Name Superior Propane Hotline	For Office Use - Party No.
Official Title	E-mail
Telephone No. 1-877-873-7467	Fax No.
Role and responsibilities in emergency Identify and dispatch Superior Propane and or LPERGC emergency response personnel as required.	
Propane Supplier Address 251 Woodlawn Road West, Unit 217, Guelph, ON	

4. Local Fire Services - Alternate Contact

Name James Ouellette	For Office Use - Party No.
Official Title Deputy Fire Chief	E-mail jouellette@amherstburg.ca
Telephone No. 519-736-6500	Fax No. 519-736-5403
Role and responsibilities in emergency Alternate - Coordinate/advise on Fire Service response and liaise with police and CTC contact.	
Fire Services Address 271 Sandwich St. South Amherstburg, ON N9V 2A5	

8. Municipal Contact

Name Stephen Brown	
Official Title Chief Building Official	
Telephone No. 519-736-5408, Ext. 247	Fax No. 519-736-9859
E-mail sbrown@amherstburg.ca	
Municipality Name and Address Development Services Dept., 271 Sandwich Street South, Amherstburg, On. N9V 2A5	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.
Emergency Shut Off push button to shut down pump and close solenoid valve upstream of dispensing hoses.

[Lined area for additional safety measures]

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) 2010	Print Name of Training Provider: <i>Standard Canadian Tire Emergency Training</i>	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy) 4Q 2011	Print Name of Training Provider: <i>Superior Propane or Other</i>	<i>Please Note - the industry did not have a course available last year. They are currently developing</i>
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	<i>the course content and it and its provider should be</i>
	Print Name of Instructor:	<i>be in place the 4Q of 2011.</i>

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy)	Print Name of Training Provider: <i>None</i>
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 01-06-2010	Print Name of Training Provider: <i>Abbcco Propane</i>	
	Print Name of Instructor: <i>unknown</i>	
Training Date (dd-mm-yyyy) TBA as required	Print Name of Training Provider: <i>Superior Propane, FSN Training or Other</i>	<i>Please Note - a ROT is valid for 3 years</i>
	Print Name of Instructor: <i>to be arranged as required</i>	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>John Lastoria</i>	Official Title <i>E H & S Specialist</i>	
Signature 	Telephone No. <i>416-544-7608</i>	Date (dd-mm-yyyy) <i>16-11-2011</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) 2011	Print Name of Training Provider: Standard Canadian Tire Emergency Training	
	Print Name of Instructor:	
Target Date (dd-mm-yyyy) Q1 2012	Print Name of Training Provider: Superior Propane or Other	Please Note - the industry did not have a course
	Print Name of Instructor:	in place last year. The PTI just release the course
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	material this month (Nov.) and CanadianTire agents
	Print Name of Instructor:	will be the first to be trained - 1Q 2012.

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) Q4 2011	Print Name of Training Provider: Key site contact to train staff
	Print Name of Instructor: to be arranged
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) TBA as required	Print Name of Training Provider: FSN Training or Alternate	Please Note - a ROT is valid for 3 years
	Print Name of Instructor: to be arranged as required	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
The agent/operator or alternate (both ROT staff) will contact emergency services by calling 911 and will provide warnings as outlined in the attached Propane Emergency Response Procedures placard (to be posted at site and be part of employee training). If it is safe to do so, this could involve advising neighbors to evacuate. The owner/operator may also contact Superior Propane via the emergency number identified in the ERP.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).
The agent/operator or alternate should first follow the actions in the ERP's provided herein. Staged evacuation, if the release of propane cannot be stopped by cutting electrical power, may be required. The initial muster location will be near the street entrance to the mall, on the sidewalk in front of the Sears building, away from a dispersing propane cloud. Subsequent evacuation instructions potentially up to the Hazard Distance to be provided by municipal emergency responders. Residences and businesses beyond the site boundary to be notified by municipal emergency responders.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).
When the system is operational, site staff will be on duty and be in the propane tank area. The Key Contact or alternate will be implementing ER actions and notifications, including notifying emergency responders. Calling 911 will occur immediately after any attempts to shut down the system.
When the system is not in operation, the ISC valve (main isolation valve) is closed, and the propane system is unattended, but is shutdown.
Any accidents involving the propane tank during such times will require the intervention of random, nearby individuals.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.
The propane tank system is located in an open area that is easily accessible from Sandwich Street.
The access routes for fire trucks are identified in the attached site plan.

Describe how the licence holder will ensure continual flow of updated information to authorities.
The critical information required from the license holder is information on how to shut the system down and the fill level in the tank (if known).
This will be provided by agent - Chris Berthiaume, verbally if on-site, or by cell phone during off hours.
Fill level is relevant from a time-to-BLEVE perspective (a near empty tank will BLEVE sooner than a full tank if there is fire impingement on the tank).

How long will it take the facility liaison person to respond to the site.
It would take the 24 hour contact, Chris Berthiaume, approximately 40 minutes to arrive on-site after having received the emergency call.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<u>75 m</u>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<u>N/A</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist	
Signature 	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes

No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by: _____ (dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist	
Signature 	Telephone No. 416-544-7608	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy)	Capacity of single largest propane storage vessel (USWG)
10-11-2011	2000 USWG
Tank setback coordinates. Indicate placement on the map.	
Front: <u>31 m</u>	Right side property line: <u>9 m</u>
Rear: <u>4 m</u>	Left side property line: <u>32 m</u>
GPS coordinates of single largest vessel:	<u>42.097601 Long. -83.10816</u>

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
John Lastoria	E H & S Specialist	
Signature	Telephone No.	Date (dd-mm-yyyy)
	416-544-7608	16-11-2011

481 SANDWICH STREET SOUTH
 TORONTO ONTARIO N 9V 3K8

P. I. N. 7 0 5 6 7 - 0 1 5 5

PROPERTY LINE
 GASOLINE PUMPS & KIOSK


UNDERGROUND GASOLINE TANKS (7500 LITRES CAPACITY)

⊕ FIRE EXTINGUISHER
 ▲ EMERGENCY STOP BUTTON
 ⚡ FIRE HYDRANT

ACCESS/EGRESS

ACCESS/EGRESS

SCALE 1:100



GENERAL NOTES

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.

STORM SEWERS

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.

SANITARY SEWERS

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.

WATERMANS

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO.

LEGEND

EX. SANITARY SEWER	EX. SANITARY SERVICE
EX. STORM SEWER	EX. STORM SERVICE
EX. WATER MAIN	EX. WATER SERVICE
EX. GAS MAIN	EX. GAS SERVICE
EX. 150mm PVC	EX. 150mm PVC
EX. 100mm PVC	EX. 100mm PVC
EX. 75mm PVC	EX. 75mm PVC
EX. 50mm PVC	EX. 50mm PVC
EX. 25mm PVC	EX. 25mm PVC
EX. 150mm STM	EX. 150mm STM
EX. 100mm STM	EX. 100mm STM
EX. 75mm STM	EX. 75mm STM
EX. 50mm STM	EX. 50mm STM
EX. 25mm STM	EX. 25mm STM
EX. 150mm W.M.	EX. 150mm W.M.
EX. 100mm W.M.	EX. 100mm W.M.
EX. 75mm W.M.	EX. 75mm W.M.
EX. 50mm W.M.	EX. 50mm W.M.
EX. 25mm W.M.	EX. 25mm W.M.
EX. 150mm S.S.	EX. 150mm S.S.
EX. 100mm S.S.	EX. 100mm S.S.
EX. 75mm S.S.	EX. 75mm S.S.
EX. 50mm S.S.	EX. 50mm S.S.
EX. 25mm S.S.	EX. 25mm S.S.
EX. 150mm C.C.	EX. 150mm C.C.
EX. 100mm C.C.	EX. 100mm C.C.
EX. 75mm C.C.	EX. 75mm C.C.
EX. 50mm C.C.	EX. 50mm C.C.
EX. 25mm C.C.	EX. 25mm C.C.
EX. 150mm A.S.	EX. 150mm A.S.
EX. 100mm A.S.	EX. 100mm A.S.
EX. 75mm A.S.	EX. 75mm A.S.
EX. 50mm A.S.	EX. 50mm A.S.
EX. 25mm A.S.	EX. 25mm A.S.



NO.	REVISION	DATE
1	ISSUED FOR PERMIT	2007
2	ISSUED FOR PERMIT	2007
3	ISSUED FOR PERMIT	2007
4	ISSUED FOR PERMIT	2007
5	ISSUED FOR PERMIT	2007
6	ISSUED FOR PERMIT	2007
7	ISSUED FOR PERMIT	2007
8	ISSUED FOR PERMIT	2007
9	ISSUED FOR PERMIT	2007
10	ISSUED FOR PERMIT	2007

PROPOSED GAS BAR

SITE SERVING PLAN

481 SANDWICH STREET S.
 AMHERSTBURG - ONTARIO

DATE: FEB. 2007

SCALE: 1:100


SS-1

CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS AND BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF TORONTO AND THE PROVINCE OF ONTARIO BEFORE COMMENCING WORK. PRINTS ARE NOT TO BE COPIED OR REPRODUCED WITHOUT THE WRITTEN PERMISSION OF TROW ASSOCIATES INC.

©2011 Google - Imagery
 ©2011 Digital Globe, Cnes/Spot Image, First Base
 Solutions,
 Map data ©2011 Google, Tele Atlas



Scale (m):



Site Boundary

2000 USWG
 Propane Tank

Hazard Distance =
 246 m

East: 4 m
 West: 32 m

Setback Distances
 to Site Boundary

North: 32 m East: 4 m
 South: 9 m West: 31 m

Capacity of Propane Storage Tank

Capacity of Propane Storage Tank = 2000 USWG

GPS Co-ordinates of Propane Storage Tank

GPS Co-ordinates = 42.097601, -83.10816

Circular Distance to 1 psi overpressure

Denoted by circle centred on tank; radial distance = 246 m

Municipality (ies) within the 1 psi overpressure circle

Town of Amherstburg

Municipal Contact

Pam Malott
 Chief Administrative Officer
 271 Sandwich St. South
 Amherstburg, ON N9V 2A5
 Phone 519-736-0012 ext 228
 Fax 519-736-5403
 email - pmalott@amherstburg.ca

Map of Surrounding Area

Canadian Tire Corporation
 421 Sandwich Street South
 Amherstburg, ON N9V 3K8

Parcel Block B-1, Section M-83, Block B,
 Plan M-83 Amherstburg

Drawn by: K. Almey Date: November 10, 2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>None in Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. [Redacted]				X	<u>75</u> m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>Sir Isaac Brock Plaza and Walmart Supercentre both with multiple retailers and restaurants</u> Address: <u>Sandwich Street and Pickering Road</u> City: <u>Amherstburg</u> Province <u>ON</u> Postal Code _____				X	<u>12</u> m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: <u>None in Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: <u>James H Sutton Funeral Home</u> Address: <u>Sandwich Street, left side of Canadian Tire facility</u> City: <u>Amherstburg</u> Province <u>ON</u> Postal Code _____		X			<u>30</u> m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: <u>None within Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) John Lastoria	Official Title E H & S Specialist
Signature 	Telephone No. 416-544-7608
	Date (dd-mm-yyyy) 16-11-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	48	279 USWG
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			279 USWG

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
2000 USWG	1	2000 USWG
Total Tank Capacity		2000 USWG

Total Cylinder Capacity	279 USWG
Total Tank Capacity	2000 USWG
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	2279 USWG