

December 2000

Regulatory Bulletin

***Adoption of ULC-ORD-C80.1-2000  
Aboveground Non-Metallic Tanks for Fuel Oil***

The Underwriters' Laboratories of Canada (ULC) has recently announced the publication of the standard ULC-ORD-C80.1-2000, "Aboveground Non Metallic Tanks for Fuel Oil." This standard is hereby adopted for use in the province of Ontario under the Fuel Oil Code of the Energy Act.

Aboveground non-metallic tanks must bear the label of a recognized certification organization confirming compliance with the ULC-ORD-C80.1. Installations of such tanks shall comply with the manufacturer's certified installation instructions and the CSA-B139-M91, "Installation Code for Oil Burning Equipment."

This bulletin is effective as of December 1, 2000.

APPROVED BY:

\_\_\_\_\_  
Michael Philip, P.Eng.  
Director, Energy Act

Distribution: COHA, TAC-Fuel Oil

L:\FSES\RS\FUELOIL\FUEL OIL BULLETIN DECEMBER 2000.DOC

**Superseded**