



Fuels Safety Program	Ref. No.: FS-108-07	Rev. No.:
Fuel Oil Code Adoption Document - Amendment	Date: October 11, 2007	Date:

***IN THE MATTER OF:
THE TECHNICAL STANDARDS AND SAFETY ACT, 2000,
S.O. 2000, c. 16 (the "Act")***

- and -

**ONTARIO REGULATION 223/01
(Codes and Standards Adopted by Reference) made under the Act**

- and -

ONTARIO REGULATION 213/01 (Fuel Oil) made under the Act

Subject: Amendment to the *Ontario installation code for oil-burning equipment* adopted by reference by the Fuel Oil Code Adoption Document adopted as part of Ontario Regulation 213/01 (Fuel Oil).
Sent to: Posted on TSSA's Web-Site.

The Director of Ontario Regulation 213/01 (Fuel Oil) pursuant of section 5 of Ontario Regulation 223/01 (Codes and Standards Adopted by Reference) hereby provides notice that the Fuel Oil Code Adoption Document published by the Technical Standards and Safety Authority, dated June 1, 2001 and amended by Director's Order FS-093-06 dated January 3, 2007 is further amended as follows:

1. Clause 13.2.2.1 is revoked and the following substituted:

Metallic end outlet tanks installed outdoors, test for water at the bottom of the tank. When water is found, remove the water.

2. This amendment will be effective on October 11, 2007.

Dated at Toronto this 11th day of October 2007.

John R. Marshall
Director, Ontario Regulation 213/01 (Fuel Oil) made under
The Technical Standards and Safety Act, 2000