

Division Name: Fuels Safety Division

Release Date: 01/98



Installation Of Air Conditioning Units On Gas/Propane Fired Furnaces

Instances have been found in which additional, alternate or replacement control devices installed on gas or propane furnaces have been incorrectly wired, resulting in bypassing safety limit controls.

From investigations conducted into some of these instances it becomes apparent that the prime cause has been failure to read and follow the manufacturer's wiring instructions.

We would like to remind you that any person who alters any appliance including electrical wiring on an appliance requires a certificate for the purpose under the Energy Act.

Please contact Mr. Z. Fraczkowski at Technical Standards and Safety Authority, telephone (416) 325-1681 for further clarification.