



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site


Failure to fully complete this form may result in rejection.
 Making a false statement may result in a fine or prosecution under the Technical Standards and Safety Act

Licence Number: 0076454073-C

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act, Propane Storage and Handling Regulation.*

Company Name: Shamrock Service Centre Ontario Corporation No., if applicable: 1429774

Operator Name (if different from above): Gregory Tibbitts

Telephone No.: 705-457-1633 Fax No.: 705-457-1917 E-mail: flybuddy@hotmail.com

Street No.: 42 Street Name / 911 Number / Address, if applicable: Highland Street

Town / City or Township / County: Haliburton Province: Ontario Postal Code: K0M-1S0

Mailing address if different from above.

Street No.: _____ Street Name / 911 Number / Address, if applicable: P.O. Box 955

Town / City or Township / County: Haliburton Province: Ontario Postal Code: K0M-1S0

Information on Container Refill Centre or Filling Plant

Location of facility.


Street No.: 42 Street Name / 911 Number / Address, if applicable: Highland Street Nearest Major Intersection: Highland Street and County Road #1

Town / City or Township / County: Haliburton Province: Ontario Postal Code: K0M-1S0

Name of Licence Holder: Gregory Tibbitts


Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT): Gregory Tibbitts ROT type: 100-08

Municipality (or municipalities if the facility or its hazard distance touches multiple borders): Municipality of Dysart et al

Hours of operation: 

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of Licence Holder: <u>Gregory Tibbitts</u>	Signature: 	Date (dd-mm-yyyy): <u>25-10-2011</u>
Name of Senior Management person as defined in the Regulation holding the Record of Training: _____	Signature: _____	Date: _____



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 1996
Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. No Modification

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	250 PSIG	7120
Tank 2:		
Tank 3:		

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 1996 USWG Portable: 263.5 USWG Mobile: _____



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner	
Signature <i>Gregory Tibbitts</i>	Telephone No. 705-457-1633	Date (dd-mm-yyyy) 25 10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) Superior Propane		For Office Use - Party No.	
Street No. 6722	Street Name / 911 Number / Address, if applicable Hwy #7		
Town / City or Township / Country Peterborough		Province Ontario	Postal Code K9J-6X5
Telephone No. 705-927-2234	Fax No.	Contact Name Mark Wakeford	
E-mail wakeform@superiorpropane.com			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>		For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage None		Capacity stored off-site, in USWG	For Office Use - Party No.
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts		Official Title Owner	
Signature 	Telephone No. 705-457-1633	Date (dd-mm-yyyy) 25-10-2011	



Technical Standards and Safety Authority
www.issa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN
The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.
 #1) Two 22,700 L underground storage tank (UST) for gasoline located on the front (North) side of the building. #2) One 15,000 L UST for gasoline located on the front (North) side of the building. #3) Stock pile of scrap tires located on the east side of the building near the property line. #4) One Aboveground 900 L Furnace Oil Tank at rear (South) side of building utilized for building heat. #5) Five 100 lb Propane Cylinders at rear (South) side of building utilized for building heat. Note: One empty 900 L Furnace Oil Tank, and one empty 2,273 L stove oil tank located at rear (South) side of building that are not in service.

Description of fire and emergency equipment indicated on facility site map.
 One ABC Fire Extinguishers is located at the propane filling station.
 One ABC Fire Extinguishers are located inside the auto tire garage bay.
 One ABC Fire Extinguishers are located inside the tire showroom.
 One ABC Fire Extinguishers are located inside the gas bar / convenience Store.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.
 1. Fusible Link connected to the ISC valve. The fusible link will melt at 212 F degrees and releases the cable that holds the spring loaded ISC Valve open, causing the ISC Valve to close and stop the flow of propane at the outlet opening located at the base of the tank.

Maintenance and testing schedule for fire protection controls and devices.
 1. Pumps (Pump every 3 months; Pump Motor: check belts monthly; grease motor every 6 months)
 2. ISC Valve (test for closure every 6 months)
 3. Storage tank relief valves – inspect every 2 years; replacement schedule as per provincial regulations.
 4. The ABC fire extinguishers are tested and maintained annually.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name Gregory Tibbitts	For Office Use - Party No.	Name Gregory Tibbitts	For Office Use - Party No.
Official Title Owner / Manager		Official Title Owner / Manager	
Telephone No. 705-457-1633	Fax No. 705-457-1917	Cell No.	Fax No. 705-457-1917
E-mail flybuddy@hotmail.com		E-mail flybuddy@hotmail.com	
Role and responsibilities in emergency Coordinate site response.		Role and responsibilities in emergency Coordinate site response.	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name Joanne King	For Office Use - Party No.	Name Gregory Tibbitts	For Office Use - Party No.
Official Title Assistant Manager		Official Title Owner / Manager	
Telephone No. 705-457-1633	Fax No. 705-457-1917	Telephone No. 705-457-1633	Fax No. 705-457-1917
E-mail		E-mail flybuddy@hotmail.com	
Role and responsibilities in emergency Coordinate site response if Key Contact person not available.		Role and responsibilities in emergency Coordinate site response.	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name Miles Maughan	For Office Use - Party No.	Name Superior Propane Hotline	For Office Use - Party No.
Official Title Fire Chief	E-mail mmaughan@dysartetal.ca	Official Title	E-mail
Telephone No. 705-457-2126	Fax No. 705-457-1964	Telephone No. 1-877-873-7467	Fax No. N/A
Role and responsibilities in emergency Coordinate/advise on Fire Service Response.		Role and responsibilities in emergency Identify and dispatch Superior Propane and or LPERGC emergency response personnel.	
Fire Services Address 5 South Street, Haliburton, Ont., K0M-1S0		Propane Supplier Address	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name Don Stevenson	For Office Use - Party No.	Name Patricia E. Martin	
Official Title Deputy Fire Chief	E-mail	Official Title Municipal Planner	
Telephone No. 705-457-2126	Fax No. 705-457-1964	Telephone No. 705-457-1740	Fax No. 705-457-1964
Role and responsibilities in emergency Alternate - Coordinate/advise on Fire Service Response.		E-mail pmartin@dysartetal.ca	
Fire Services Address 5 South Street, Haliburton, Ont., K0M-1S0		Municipality Name and Address Dysart et al, 135 Maple Avenue, Box 389, Haliburton, Ont., K0M-1S0	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

There is not anything over and above code that is in place at this facility. The propane pump, and valves for the propane tank is secured inside a ventilated cabinet beneath the tank, with a lockable cabinet door. The Propane tank is protected by posts, and all access to the tank is made clear.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts		Official Title Owner	
Signature 		Telephone No. 705-457-1633	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) None	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) None	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 31-08-2011	Print Name of Training Provider: E. Grigg and Associates / OPA	Please Note: an ROT is valid for 3 years.
	Print Name of Instructor: E. Grigg	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) TBA Q4 (2011)	Print Name of Training Provider: Superior Propane or Alternate	Please Note – the course content is currently being developed by the TSSA and should be available for teaching in the fourth quarter of this year.
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	available for teaching in the fourth quarter of this year.
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) TBA Q4 (2011)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) As Required	Print Name of Training Provider: Superior Propane, FSN, or other.	Please Note - An ROT is valid for 3 years.
	Print Name of Instructor: TBA	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
At this time Greg Tibbitts and Joanne King are the only persons that hold an ROT, and one or both are always present at the facility during business hours.

The ROT person(s) on duty will implement the propane "Emergency Response Plan" (ERP), and will contact emergency services by calling 911 and will provide warnings outlined in the (ERP) placard, if it is safe to do so.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

Actions and warnings will be taken by the ROT person(s) on duty, as per the attached ERP placard.

All persons on site will be evacuated to the Muster location is 93 metres from the propane tank, at the Float Plane Dock on the shoreline of Head Lake, located on the north side Highland Street and in direct line of Shamrock Service Centre, and there will wait for the Emergency Services to arrive.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

When the system is operational, the ROT person on duty and be in the propane tank area. This person will be able to visually ascertain any abnormal / accident events and implement the appropriate emergency response actions as outlined in the Emergency Response Procedures Placard. When the propane system not operating, the ISC valve located at the bottom outlet opening at the base of the tank is closed, and the propane system is unattended. Any accidents involving the propane tank during such times will require the intervention of random, nearby individuals or staff, or the owner lives at the site.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

Entry onto the property is only from Highland Street and is clear at all times to enter onto the property. The propane tank is located on the east side and southern half of the property, and access to the tank is kept clear.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The license holder will liaison with the Emergency Responders and inform them of the situation and provide the critical information of how much propane is in tank, and if there is any concern about other storage on the property.

This information will be provided to the authorities by the agent - Greg Tibbitts, time permitting.

How long will it take the facility liaison person to respond to the site.

1 minute, as the licence holder works and lives at this place of business.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner	
Signature 	Telephone No. 705-457-1633	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<u>93 metres</u>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<u>1,100 metres</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services	Yes	No
Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?	<input type="checkbox"/>	<input type="checkbox"/>
If not, please explain (e.g., no fire services).		
Fire services comments, if any:		
To be completed by the Licence Holder		
In response to the above comments, the following action(s) is required:		
The licence holder will respond to the Local Fire Services comments by: _____		
(dd-mm-yyyy)		

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner	
Signature 	Telephone No. 705-457-1633	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 20-10-2011	Capacity of single largest propane storagevessel (USWG) 1996 USWG
Tank setback coordinates. Indicate placement on the map.	
Front: 34.4 m (North)	Right side property line: 5.2 m (East)
Rear: 16.3 m (South)	Left side property line: 29.9 m (West)
GPS coordinates of single largest vessel: Lat. 45.0436 Long. 78.5177	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Gregory Tibbitts	Official Title Owner
Signature 	Telephone No. 705-457-1633
	Date (dd-mm-yyyy) 25-10-2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>Head Lake Park</u> Address: <u>Highland Street</u> City: <u>Haliburton</u> Province <u>Ontario</u> Postal Code <u>K0M 1S0</u>		x			<u>54.5</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. [Redacted]				x	<u>35.1</u> m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>Shamrock Service Centre</u> Address: <u>42 Highland Street</u> City: <u>Haliburton</u> Province <u>Ontario</u> Postal Code <u>K0M 1S0</u>			x		<u>6.7</u> m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: <u>Silver Maple Motel</u> Address: <u>48 Highland Street</u> City: <u>Haliburton</u> Province <u>Ontario</u> Postal Code <u>K0M 1S0</u>		x			<u>7.3</u> m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	x				_____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Gregory Tibbitts</u>	Official Title <u>Owner</u>
Signature 	Telephone No. <u>705-457-1633</u> Date (dd-mm-yyyy) <u>25-10-2011</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5	5	147.5
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	20	116
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			263.5


Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	263.5
Total Tank Capacity	
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	2259.5

Note: Site on Google was not too clear and the Aerial map did not show a clear location of buildings as they exist. The photos give a clear concept of the site


©2011 Google – Imagery
 ©2011 Digital Globe, One/Spot Image, First Base Solutions,
 Map data ©2011 Google, Tele Atlas



2000 USWG
 Propane Tank

Property Line

Hazard Distance = 246 m



Setback Distances to Site Boundary	North : 34.4 m South: 16.3 m	East: 5.2 m West: 29.9 m
Capacity of Propane Storage Tank	Capacity of Propane Storage Tank = 2000 USWG	
GPS Co-ordinates of Propane Storage Tank	GPS Co-ordinates = 45.0436 -76.5177	
Circular Distance to 1 psi overpressure	Denoted by circle centred on tank; radial distance = 246 m	

Municipality (yes) within the 1 psi overpressure circle
 Municipality of Dysart et al

Municipal Contact
 Patricia Martin, Municipal Planner
 135 Maple Avenue, Box 389 Hailburton, ON, K0M 1S0
 Tel: 705-457-1740 Fax: 705 457-1964
 Email: pmartin@dysartet.al.ca

Map of Surrounding Area

Shamrock Service Centre (Shell)
 42 Highland Street, Hailburton, ON, K0M 1S0

LEGAL DESCRIPTION:
 CON. S. PRT. LOTS, PLANNED 2744 PRT I
 IN THE MUNICIPALITY OF DYSA ET AL.

Drawn by: G. Bindisi Date: October 20, 2011

- Legend:**
- FE: ABC Fire Extinguisher
 - PCST: Propane Cylinder Storage Area
 - UST 1: 15,000 L Gasoline Underground Storage Tank
 - UST 2: 22,700 L Gasoline Underground Storage Tank
 - UST 3: 22,700 L Gasoline Underground Storage Tank
 - GPI: Gasoline Pump Island
 - FO: 900 L Aboveground Furnace Oil Tank for Building Heat
 - PC: Propane Cylinders for Building Heat

