

Technical 14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X XX4 Fax: 416.231.4903 customer Service: 1.877.682.8772

Level-1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

This Level 1 RSMP applies to: a facility with a total propane storage capacity of 5,000 USWG or less; or a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

_	En	ilima An fully named to 111 A	***************************************		
	Mal	allure to fully complete this for king a false statement may res	tilt in a fine or proposition		
		under the Technical Stand	lards and Safety Act		
		000180717			
Chec	k applicable type of	propane operations.			
	✓ Cylinder	Motor Fill	Filling Plant	ard/Kevlock	
Subn	nit along with this co	impleted application a Facility Site I	Plan and a Map of the Surroundin	g Area.	
1.5	THE SHAPE		CTION AT GENERA	L INFORMATION	
The	Indeveloped			-	
Pro	pane Storage	applies to TSSA for a and Handling Regulat	review for an RSMP u	ınder Ontario's <i>Technic</i>	al Standards and Safety Act,
	Company Name	, and managing Hegulat	ion,		920000 N D
A	P. & R. Hofstatt	er Sales Inc.			Ontario Corporation No., if applicable
	Control of the contro	different from above)			
	Pierre Hofstatte	r			1627
	Telephone No.	Fax No.	, E-mail	<del></del>	
	613-267-3412	613-267-0024	ctc080@aol.com		ĺ
В	StreetNo.	Street Name / 911 Number /	Address, if applicable		
	45	Dufferin Street	E Mag		· ·
	Town / City or Toy	wnship / County		Province	Postal Code
	Perth			Ontario	K7H 3A5
		s if different from above.			
C	StreetNo.	Street Name / 911 Number	Address, if applicable		Ī
	Town / City or Town	nship / County		Province	
			13	Province	Postal Code
Inf	ormation on Co	ontainer Refill Centre or F	illing Plant		
	Location of facility Street No.	•			
D	45	Street Name / 911 Number /	Address, if applicable	Nearest Major Inters	ection
9		Dufferin Street		HWY 7 & WILSON	
	Town / City or Towr	nship / County		Province	Postal Code
	Perth			Ontario	K7H 3A5
	Name of Licence Ho				
1					7
L	P. & R. Hofstatter				
1	Name of a Senior IV	flanagement person as defined in t	ne regulation holding the Record	of Training (ROT).	ROT type
L	Pierre Hofstatter				
1	Municipality (or municipalities if the facility or its hazard distance touches multiple borders)				
I.	100000 c	if Perth (	wanty of	LANARK	La Marie Contraction
5	Hours of operation.	1		N. W.	The grant of
23	Hours of operation.				
	38				

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.

Printname	- Signature-	Date (dd-mm-yyyy)
Name of Licence Holder Pierre Hofstatter	A DI	18-08-2011
Name of Senior Management person as defined in the Regulation holding the Record of Training		18/08/2011
09195 (11/10) Page 1 of 15	XVII	



Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority
www.tssa.org Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

SE	CTION A: GENERAL INFORMATION (cont.d)	
Indicate the year the facility was established.	Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment.	
Identify the psig rating and serial number for ea	ach fixed propane storage tank on site.	
PSIG / O	Serial Number	
	SN7148	
Tank2:	Note: you will find the PSIG and Serial number on the propone tank.	
Tank3:		
Enter capacity of propane in USWG, fixed, porta	table, and mobile, and provide detailed inventory that includes the number of tank/vessel for	
each type (fixed, portable, and mobile) and the	capacity of each tank/vessel, on a separate document.	
Fixed: 2000	140	
	Portable: Mobile:	
		W- 3000

Name of person completing this form (please print)	Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
09195 (11/10) Page 2 of 15	613 267 3412	18-08-2011



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act
Propane Storage and Handling Regulation

No Action required

#### SECTION A: GENERAL INFORMATION (CONFG)

Activity Information Name of Propane Supplier(s) Superior Propane - Ontario Regional Operations Centre Street No. Street Name / 911 Number / Address, if applicable 251 Woodlawn Road West, Unit 217 Town / City or Township / Country Province Guelph Postal Code Ontario N1H 8J1 Telephone No. Fax No. Contact Name 1-877-873-7467 519-836-7766 Mike Mullins E-mail mullinsm@superiorpropane.com Name of Propane Transporter. If same as above, please check box. For Office Use - Party No Superior Propane - Ottawa Propane Bulk Plant Street Name / 911 Number / Address, if applicable Street No. 63 Roydon Place Town / City or Township / Country Nepean Province Postal Code Ontario K2E 1A3 Telephone No. Fax No. Contact Name 1-877-873-7467 Heather Ross E-mail rosshe@superiorpropane.com Off-site Cylinder and/or Mobile Storage Capacity stored off-site, in USWG For Office Use - Party No. Street No. Street Name / 911 Number / Address, if applicable Town / City or Township / Country Province Postal Code Telephone No. Fax No. Contact Name Note: Customer storage is not considered off-site storage.

Name of person completing this form (please print) Pierre Hofstatter Signature	Official Title Dealer	
FS 09195 (11/10) Page 3 of 15	Telephone No. 613 267 3412	Date (dd-mm-yyyy) 18-08-2011



Technical Standards and Safety Authority Fax: 416.231.4903 www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

#### SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Waste glycol tank in compound behind shop (2,000 litres). Oxygen tank (1) and Acetolyne tank (1) in shop tool room.  Gas Bar - Tanks 1&2 Regular 32,000 liters each, Tank #3 Diesel 22,000 liters, Tank #4 Premium 24,000 liters and 1 cage of 24 20lb propane tanks  Description of fire and emergency equipment indicated on facility site map.  I x 10 lb. fire extinguishers at propane compound.  Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Ist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Dynamic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Il standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.	
Cas Bar - Tanks 1&2 Regular 32,000 liters each, Tank #3 Diesel 22,000 liters, Tank #4 Premium 24,000 liters and 1 cage of 24 20lb propane tanks  Description of fire and emergency equipment indicated on facility site map.  I x 10 lb. fire extinguishers at propane compound.  Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Sist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Production of fire and emergency equipment indicated on facility site map.  I x 10 lb. fire extinguishers at propane compound.  Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Sist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Production of fire and emergency equipment indicated on facility site map.  I standple these from the fire detection of fire devices are notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  I standple test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Il standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, repump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft,  Further staff further staff further test, control unit inspection, battery test and inspection December 2011 (Control unit test record, power supply inspection, fifter test, ancillary device test and device testing	Description of the maximum volume, types and storage location of other hazardous materials on site, if any.  Bulk oil containers Bay 1 - 5W30 (max 1000 litres. Bay 2 5W20 Max 1000 litres. Waist oil tank in compound behind shop (2500 litres)
Description of fire and emergency equipment indicated on facility site map.  In x 10 lb. fire extinguishers at propane compound.  Service Centre - 4 x 5lb. extinguishers  If en hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  It is of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Poynamic Electric & Fire Protection in for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  It standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  It is another than the system is specified by the system is specified by the system, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  If is a system is the system is specified by the system is specified	Waste glycol tank in compound behind shop (2,000 litres). Oxygen tank (1) and Acetolyne tank (1) in char task recers
Description of fire and emergency equipment indicated on facility site map.  I x 10 lb. fire extinguishers at propane compound.  Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Ist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Popularic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Complete test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Il standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  Istandance and testing schedule for fire protection controls and devices.  Popularic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, and there exit, ancillary device test and device testing	Gas Bar - Tanks 1&2 Regular 32,000 liters each, Tank #3 Diesel 22 000 liters Tank #4 Promitive 24 000 liters
Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Fire hose hookup behind Service Centre for Main Store.  Fire hose hookup behind Service Centre for Main Store.  Fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  Fire protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Formplete test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  Fire protection Inc for fire protection controls and devices.  Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, battery test and inspection, annunciator test, sequential display test, remove trouble unit test, differences, ancillarly device test and device testing	tanks Lajour illors, Tank #4 Fremium 24,000 liters and 1 cage of 24 20lb propane tanks
Service Centre - 4 x 5lb. extinguishers  Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign  Fire hose hookup behind Service Centre for Main Store.  Fire hose hookup behind Service Centre for Main Store.  Fire hose hookup behind Service Centre for Main Store.  Fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.)  For protection, use and operation.  For protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  For protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  For pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire pulliding fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Fire protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Fire protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Fire protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Fire protection inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguisher	Description of fire and emergency equipment indicated on facility site map. 1 x 10 lb. fire extinguishers at propane compound.
ist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.  Synamic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Somplete test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Il standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  Islantenance and testing schedule for fire protection controls and devices.  Synamic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, interest, ancillary device test and device testing	Service Centre - 4 x 5lb. extinguishers
ist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.  Synamic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Somplete test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack  Il standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  Islantenance and testing schedule for fire protection controls and devices.  Synamic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, interest, ancillary device test and device testing	Fire hydrants - 1 x staff parking lot, 1 x highway 7 by road sign
ist of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.  Synamic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Somplete test for building fire alarm system and voice communication system, inspect plugs, caps on standpipe system, hose valves, re-stack is standpipe hose, sprinkler pipe hangers, sprinkler heads, drip drums, dry pipe sprinkler system, lubricate fire dept connections, sprinkler alarm test, re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.  According to the system of the sy	Fire hose hookup behind Service Centre for Main Store
re pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at top of smoke shaft.    Application of the protection controls and devices     Application of the protection controls and devices	Dynamic Electric & Fire Protection Inc for Main Store - test emergency lighting equipment, maintenance procedures for extinguishers.  Complete test for building fire alarm system and voice communication system, inspect plans, and the communication system.
daintenance and testing schedule for fire protection controls and devices.  Dynamic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, power supply inspection, annunciator test, ancillary device test and device testing	Pipe trangers, sprinkler neads and drime dry pine enviables and the second
destrict and testing schedule for fire protection controls and devices.  Advisory for the Shuffing of Supply for Synamic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection, poice communication test, control unit inspection, battery test and inspection, annunciator test, sequential display test, remove trouble unit test, interest, ancillary device test and device testing	ire pump flow test, inspect hydrants, hydrant water flow, flow test all fire hydrants and closures at ten of arrates at a confections, sprinkler alarm test,
A County	Dynamic Electric & Fire Protection Inc for Main Store - Yearly inspection December 2011 (Control unit test record, power supply inspection,
	ritner test, ancillary device test and device testing
· · · · · · · · · · · · · · · · · · ·	

Name of person completing this form (please print) Pierre Hofstatter	Official Title	
Signature	Dealer	4
	Telephone No.	Date (dd-mm-yyyy)
FS 09195 (11/10) Page 4 of 15	613 267 312	18-08-2011



Technical Standards and

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Fax: 416.231.4903 Toronto Ontario M8X2X4 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

Verify Information entered is accurate. Obtain information for #2, 3, 4 and 8

	The state of the s	Energy response	ERLAN (corne)
Research Commencer (Commencer)	*		
Name Pierre Hofstatter		Rame	On Control of the Con
Official Title Dealer	Editoriise biscos Pantynos a	Pierre Hofstatter Official Title	For Olice Use: Party No. 14
Telephone No.	Fax No.	Dealer	16.5
613-267-3412 · E-mail	613-267-0024	Cell No.	Fax No.
ctc080@aol.com		E-mail	613-267-0024
Role and responsibilities in emergency			
Co-ordinate site response.	,	Role and responsibilities in emerger Co-ordinate site response.	ncy
	The second second		4
Name		Calding Challed History	76% (S. )
Dave Hall Official Title		Name Plerre Hofstatter	
Official Title Service / Safety Manager	STATE OF THE PROPERTY OF THE P	Official Title	Do Office Use - Harryene
Telephone No. 613 267 3412	Fax No.	Dealer	
E-mail	613 267 0024	Telephone No. 613-267-3412	Fax No. 613-267-0024
daveservman@yahoo.ca		E-mail	013-267-0024
Role and responsibilities in emergency		ctc080@aol.com	
Co-ordinate site response if Dealer not a	vailable.	Role and responsibilities in emergen Co-ordinate site response.	cy
CAROLINE PROCESSOR SERVICE			
Name		7. Program Spring Pray Control	
Steve Fournier Official Title		Name	
Fire Chiel, Perth, ON		Superior Propane Hotline Official Title	FOR Office Base Chair Nov. 1
Telephone No.	Fax No.		·
E-mail 3	13 267 5589	Telephone No. 1-877-873-7467	Fax No.
perthfirechief@perth.ca		E-mail	1
Role and responsibilities in emergency		Role and responsibility	
Respond to 911 call or safety questions for	or site.	Role and responsibilities in emergence	ey
November 1	( SP24 24 SECOND		
Name		te minimal constants	
Name Pete Echlin	AND THE RESERVE OF THE PROPERTY OF THE PERSON OF THE PERSO	Name	Folionice Use Pany No 1/2
Official Title Fire Prevention Officer	A.	John deRonsenroll (starts Aug 22, 201 Official Title	1)
Telephone No.		C.A.O. Perth Town Hall	_
613 267 5574 6	12 267 5500	Telephone No. 613 267 3311 X224	Fax No.
pechlin@perth.ca		E-mail	613 267 5635
Role and responsibilities in emergency		iderosenroll@perth.ca Municipality	
Respond to 911 call or safety questions fo		Town of Perth, County of Lanark	
		County of Lanaik	

Name of person completing this form (please print) Pierre Hofstatter	Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
FS 09195 (11/10) Page 5 of 15	613 267 3412	18-08-2011



Technical Standards and

14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Safety Authority Fax: 416.231.4903 Customer Service: 1.877.682.8772 Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

## SECTION B. EMERGENCY AND PREPAREDNESS RESPONSE PLAN (GONTO)

2. Additional Safety Measures

Describe any other	Measured in place at the Country of
wasty outer t	measures in place at the facility that exceed the minimum Code and Standards requirements.
N/A	
	A STATE OF THE PROPERTY OF THE
	(

Name of person completing this form (please print) Pierre Hofstatter	Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
FS 09195 (11/10) Page 6 of 15	613 267 3412	18-08-2011



Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Toronto Ontario M8X 2X4
Fax: 416.231.4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

#### SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

Record of Emergency Training Provided. For most recent 12 month period

Training on Emergency Res	poinse Plan and Proceduresprovided to facility key contacts.
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
N/A	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
	etgency Management Procedules provided to staff.
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
N/A	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
	vided to certificate holders/persons with Records of Training.
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
N/A	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Name of person completing this form (please print)	Official Title	
Pierre Hofstatter	Dealer	
Signature	Telephone No.	Date (dd-mm-yyyy)
	613 267 3412	18-08-2011



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231,4903 Customer Service: 1.877,682,8772

## Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

No action required at this time.

#### SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (contd)

4 Emergency Training Plan for Coming Year

sucumerant interest on Resi	onse Plan and Procedures provided to facility key contacts.
Target Date (dd-mm-yyyy)	Print Name of Training Provider: To Be Declarmed by years and Do
Q4 2011 34-10-12	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training on the facility's Eme	gency/Management/Procedures provided to staff
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
Q4 2011 31-10-12	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:  Print Name of Training Provider:
· · · · · · · · · · · · · · · · · · ·	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
On-site specific training provi	ded to certificate holders/persons with Records of Training.
rarger Date (dd-mm-yyyyy)	Print Name of Training Provider:
Q42011 31-10-12	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
magnagement of a part of Alberta P.O. 12	

Name of person completing this form (		ete.
Name of person completing this form (please print) Pierre Hofstatter	Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
	613 267 3412	18-08-2011
S 09195 (11/10) Page 8 of 15	The state of the s	Anna Caranta C



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X 2X4 Fax: 416.231.4903 Customer Service: 1.877.682,8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

### SECTION B. EMERGENCY AND PREPAREDNESS RESPONSE PLAN (centio)

The licence holder will complete Section Bin consultation with the local Fire Services.

5. Emergency Response Communications Plan.

Warnings and Actions Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate). Manager on duty, via public address system and portable radios for staff and customers. done in ned cadelo Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary). If an occurence happens while the store is open, the duty manager over the store loud speaker will request all staff and customers immediately leave the premises. Staff are to muster at the KFC area in the parking lot for roll call. Manager on duty will ensure that the store and staff areas have been Communication with Emergency/Response Authorities Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is When the store is open for business the Duty Manager will call 911 for emergency services. Describe provisions for fire department entry when there are no operations or staffing at the propane site. Propane site is in a large open area in parking lot. The Fire Department will not have any issues accessing the propane site. Describe how the licence holder will ensure continual flow of updated information to authorities. Forward test records to local Fire Department. Site Inspections How long will it take the facility liaison person to respond to the site. The Dealer lives 5 min. from site and Service/Safety Manager 10 minutes.

Name of person comments at a	- 3. out note to trace and comple	ste.
Name of person completing this form (please print) Pierre Hofstatter	Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
	613 267 3412	18-08-2011
FS 09195 (11/10) Page 9 of 15		



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

59	<i>N</i> GRESS	医数据 海海	C0025350000	DATAPATER	Charles Control									
	25000	PROPERTY.	STORY ST. APPRO	THE PARTY OF THE P	STATE OF THE PARTY OF	<b>企业区的企业的企业</b>	THE PERSON NAMED IN COLUMN	THE WAY TO THE PARTY OF THE PAR	Contract of the Contract of th					
A)	10751007	图mm/图45	26 33 E 60	高 化 短冠 中光	THE COURSE WARRY TO	that is a first of the second	APPROXIMATE OF THE PARTY OF THE	- Children Charles and Charles	ESTACK OF THE POST OF THE PARTY	SERVICE AND ADDRESS OF THE PARTY OF THE PART	March State and March State of the Control of the C	or London Street Walls and Building	STREET, STREET	-
æ	100	Same Co.	25 10 6 12	人民 医红白的	<b>印度经验的现在分</b> 件	S. Street, South St. Vanis Street, St. V.	TOTAL COMPANY OF THE REAL PROPERTY OF THE PARTY OF THE PA	to Kill a l to l'union l'	With March and and Mills and	A STATE OF THE PARTY OF THE PAR		100	(conta)	55E
	33 Gr	和探查方	KI SUPPLY	- Consideration	<b>1000 200 回廊里</b>	The state of the s	7 12 (18) E - 1 V V	D 10 10 10 10 10 10 10 10 10 10 10 10 10	<b>新新闻新闻的 医双侧侧</b>		J 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	200 n 7 cm . 5 V		See
23	5807+23	50X18-500X	1 C K 2 K 3 K	28 128 12 HIERON	12 Co. 1 (1)	<b>不是不是不是有一个人的。</b>	<b>阿拉克斯斯</b> 克罗斯斯斯斯	1997年1997年1997年1997年1997年1997年1997年1997	(1) (1) (1) (1) (1) (1) (1) (1) (1) (1)		> 1 to the > 1 P. ( > 1 =	stell and traff to the	Mary Hard on You have a little and I	
œν	AND COLUMN	90 ST0000	MADE VINE	State of the last	GEO MESSAGE MARRIED CO	Control of the Contro	CAMP STATE OF THE PARTY.	SEASON PROPERTY INCOME.	STORING DEVICE AND LONG	<b>经特别的</b> 自然的人是25年的特别的	resident film film to the series of the seri	de la		<i>1</i> 39

The licence holder will complete Section B in consultation with the local Fire Services. 2, st., 6: Building and Site Security and Procedures. No Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)? 2. Is there adequate night lighting at the site? Are procedures in place that ensure access routes, aisles, storage area, filling areas 3. and the grounds are kept clear from unwanted materials? Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane? 1 Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders? Are weighing systems validated for accuracy? 6. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, 7. purged and other hazardous materials)? Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves) Is the schedule of maintenance and testing activities retained on site? 9. Contact your local fire department to obtain this information. The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location. Yes No Is a pressurized water system available at the propane facility site? Can the municipal fire department pump 375 GPM (1420 LPM) of water at this 2. location? What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only) 40 Metres What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only) n/a

		ere.
Name of person completing this form (please print) Pierre Hofstatter Signature	Official Title Dealer	
	Telephone No. 613 267 3412	Date (dd-mm-yyyy)
FS 09195 (11/10) Page 10 of 15	010 207 0412	18-08-2011



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

# Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

This page is left blank and submitted to the local fire services for their review when the RSMP is complete.

#### SECTION BE EMERGENCY AND PREPAREDNESS RESPONSE PLAN (CONT. 6)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review.

To be completed by the Local Fire Services  Has the local fire service had an opportunity to review the Emergency  If not, please explain (e.g., no fire services).		es No				
Fire services comments, if any: - Fire Department familar with operations - Site tour was conducted						
- No concerns from Fire Department at this time						
To be completed by the Licence Holder In response to the above comments, the following action(s) is required: Nothing at this time.		·				
The licence holder will respond to the Local Fire Services comments by: no comments required at this time (dd-mm-yyyy)						
LOCAL FIRE SERVICES  The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.						
Print name  Local Fire Services Name Steve Fournier, Fire Chief Perth	Signature	Date (dd-mm-yyyy) 18-08-2011				

Name of person completing this form (please print) Pierre Hofstatter	Official Title Dealer		
Signature	Telephone No. 613 267 3412	Date (dd-mm-yyyy) 18-08-2011	



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231,4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

#### MANAGEMENT STONE OF STONE STON

spplicant must include a Facility Site Plan and Map of Surrounding Area.

#### Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

- ★1. The storage location of fixed, portable, and mobile vessels.
- The maximum volume, types and storage location of hazardous materials.
  - Location of permanent structures on site.
  - Access and egress points and location of barriers.
  - Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
  - Location of emergency shut off/shut down switches/valves.

#### Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

- 7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
- GPS co-ordinates of the single largest vessel.
- 9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel. 10. Clear indication of the municipality or municipalities present within the circle.
- 11. Visual indication of property line information.
- 12. The location and name of roads within or abutting the site.
- 13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the
- 14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
- 15. Complete "Required Mapping Information from Updated Site Plan" in table below .

#### Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 22-04-2005	Capacity of single largest propane storagevessel (USWG)
Tank setback coordinates. Indicate placement Front: 3 meters Rear: 3 meters	t on the map.  777 88.7 Right side property line: 3 meters 107.6  Left side property line: 3 meters 50.9750.9
GPS coordinates of single largest vessel:	44.9109, -76.265

Declaration: I am aware that it is an offence to give false information in this document and

Name of person completing this form (please print) Pierre Hofstatter	mation I have given here is true and comple  Official Title	
Signature	Dealer	
	Telephone No.	Date (dd-mm-yyyy)
S 09195 (11/10) Page 12 of 15	613 267 3412	18-08-2011



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act Propane Storage and Handling Regulation

No information needed on this page.

#### (Brich) Endlehmene 19 norde

Applicant must include a Facility Site Plan and Maplot Surrounding Area

Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula:

 $D = 16.94 \times (1.524 \times C)^{1/3}$ 

D = Distance to overpressure of 1 psi (meters)

C= Tank Total Capacity in USWG


Parameters:

Density of Propane is 0.5033 kg per litre @ 15 C

Assume all vessels are 80% full

1 gallon [US, liquid] = 0.003785411784 cubic meter

1 cubic metre = 264.17 USWG



Name of person completing this form (please print) Pierre Hofstatter	Official Title  Dealer	re.
Signature	Telephone No. 613 267 3412	Date (dd-mm-yyyy)
FS 09195 (11/10) Page 12 of 45		



14th Floor - Centre Tower 3300 Bloor Street West Toronto Ontario M8X2X4 Fax: 416.231.4903 Customer Service: 1.877.682.8772

## Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act

Propane Storage and Handling Regulation

Name the closest building of each type within the circle from the aerial map and the total number of buildings within the circle for each section.

SECTION G: SUBMISSIONS (continuity within the circle for each section.

Applicant must include a Facility Site Plan and Map of Surrounding Area.

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature		and Fo	of Build eatures th an ") 2-10	(")	Distance from Tank to Closest Building or Feature
Industrial buildings or parks or golf courses Name:					
Address: Province Postal Code	0		(je)		m
Residential building units specifically permanent single family dwellings, condominiums, and apartments.  Name:		and the same of			
City: Province Postal Code	0		٠. موم		m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes.  Name: (1) Kentucky Fried Chicken,  Address: 41 Dufferin St. K7H3A5  City: Province ON Postal Code	(to-		1	×	100 m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts.  Name: Canadian Tire Gas Bar (80m from Propane Site) and Canadian Tire Store (10m from propane site)  Address: 45 Dufferin St.  City: Perth Province ON Postal Code K7H 3A5		2			80 & 10 m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons.  Name:  Address:  City:  Province  Postal Code	0				m
Emergency responders specifically fire stations, ambulance stations, and police stations.  Name:  Address:  City:  Province  Postal Code	0				m

Name of person completing this form (please print) Pierre Hofstatter	Official Title Dealer	
Signature	Telephone No. 613 267 3412	Date (dd-mm-yyyy) 18-08-2011

<sup>\*</sup> For multi-unit buildings, count each unit as "1".



Technical Standards and www.tssa.org

14th Floor - Centre Tower 3300 Bloor Street West Safety Authority Toronto Ontario M8X2X4
Fax: 416.231.4903 Customer Service: 1.877.682.8772

#### Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

#### SECTION CONTRACTOR (CONTRI)

Applicant must include a Facility Site Plantand Map of Surrounding Area

#### Portable Storage Additional Information Sheet


Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		Totalio iii 05wg
# 100	29.5		And the second s
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	140	VID 00
# 10	2.9		012 30
# 5	1.5		
Cylinder Capacity	\$10.01		

#### Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantita	
	Quantity	Total Volume in USWG
Total Tank Capacity		
Total Cylinder Capacity	812 08	
Total Tank Capacity	012	
	2000	
Total Portable Capacity	81201	

Declaration: I am aware that it is an offence to give false information in this document and

Name of person completing this form (please print) Pierre Hofstatter Signature	on I have given here is true and comple Official Title Dealer	- CV-0
S 09195 (11/10) Page 15 of 15	Telephone No. 613 267 3412	Date (dd-mm-yyyy) 18-08-2011





Location of Propane Storage Tank:	Note: Property Lines a setbacks shown on site plan.	Map of Surro
Demarcated by in centre of circle.	Municipality (jes): within the 1 psi overpressure circle:	
		The Table Time
Capacity of Propane Storage Tank:	Lanark County municipality	Canadian life - 45 DUFFE
Capacity of Propane Storage Tank = 2000 USWG	Municipal Contact:	Legal Description: Pl
GPS Coordinates of Propane Storage Tank:	John do bates	***************************************
GPS Co-ordinates = 44.9109, -76.265	Conn secretaria	6
Circular Distance to 1 psi overpressure:	solerosenroll partica	
Denoted by circle centred on tank radial distance = 246 m	C. A. O Peter Town their	

# ounding Area

ERIN STREET PERTH

Please see attached

# LOCK UP PROCEDURES – PROPANE CTC STORE 80

- 1. Turn off ISC valve.
- 2. Close and lock cabinet doors
- 3. Install indicating "Emergency Gas Leak do not open"
- 4. Calling propane supplier to advise of circumstance

# OVERFILLED CYLINDER PROCEDURES – PROPANE CTC STORE 80

- 1. Set overfilled cylinder in locked cylinder cage.
- 2. Call Superior Propane 1 877 873 7467.
- 3. Contact name: Heather Ross
- 4. Advise Superior to make necessary arrangements to correct situation.

# <u>DAILY INSPECTION OF HOSES AND MECHANICAL</u> <u>DEVICES – PROPANE</u> <u>CTC STORE 80</u>

- 1. Check hoses for cracks or bulging.
- 2. Check for gas leaks.
- 3. Check fire extinguisher that it is on site and charged.
- 4. Check for cylinders dropped off and placed in cylinder cage.